



**ÚSTÍ NAD ORLICÍ – VEŘEJNÁ INFRASTRUKTURA
V RÁMCI REVITALIZACE ÚZEMÍ PERLA 01
V ÚSTÍ NAD ORLICÍ**

E.3 Dokladová část – Statika potrubí

STATIKA POTRUBÍ

ŽEBROVANÉ POTRUBÍ

PP D225/DN200 SN16

Název akce: Ústí nad Orlicí - Perla 01
Firma: M Projekt CZ, s.r.o.
Vypracoval:
Datum: 1.2.2019

Trubka

Typ trubky: (PP) SN 16

Označení průměru trubky DN: 200 mm

Vnější průměr trubky: 223,6 mm

Vnitřní průměr trubky: 196,4 mm

Řez stěnou



Podmínky uložení

Výška krytí zeminy nad potrubím: 1,5 m

Hladina podzemní vody nad vrcholem: 0,5 m

Šířka výkopu: 1,2 m

Úhel sklonu výkopu: 90°

Způsob pokládky: Pokládka do otevřeného výkopu

Způsob uložení potrubí a provedení zásypu: A4B4

Zemní prostředí

Okolní rostlá zemina: G1

Stupeň zhutnění (Standard Proctor) S_{pr}: 90 %

Obsypová zemina (v zóně potrubí): G1

Stupeň zhutnění (Standard Proctor) S_{pr}: 90 %

Zásypová zemina (nad zónou potrubí): G1

Stupeň zhutnění (Standard Proctor) S_{pr}: 90 %

Zatížení


Zatížení dopravou: Vozidlo - SLW30 (DIN)

Rovnoměrné plošné zatížení: 0 kN/m²

Tento výpočet je proveden dle ATV-DVWK-A 127: 2000 a nenahrazuje oficiální statické posouzení provedené autorizovaným statikem.

Název akce:	Ústí nad Orlicí - Perla 01
Firma:	M Projekt CZ, s.r.o.
Vypracoval:	
Datum:	1.2.2019

Zemní profil



Posouzení

Napětí:

Vrchol trubky - vnější povrch: $ \sigma_{v,e} = -3,84 \text{ MPa} \leq \sigma_{dov} = 8,5 \text{ MPa}$	VYHOVUJE
Vrchol trubky - vnitřní povrch: $ \sigma_{v,i} = 0,99 \text{ MPa} \leq \sigma_{dov} = 8,5 \text{ MPa}$	VYHOVUJE
Bok trubky - vnější povrch: $ \sigma_{b,e} = 1,68 \text{ MPa} \leq \sigma_{dov} = 8,5 \text{ MPa}$	VYHOVUJE
Bok trubky - vnitřní povrch: $ \sigma_{b,i} = -1,87 \text{ MPa} \leq \sigma_{dov} = 8,5 \text{ MPa}$	VYHOVUJE
Pata trubky - vnější povrch: $ \sigma_{p,e} = -4,72 \text{ MPa} \leq \sigma_{dov} = 8,5 \text{ MPa}$	VYHOVUJE
Pata trubky - vnitřní povrch: $ \sigma_{p,i} = 1,35 \text{ MPa} \leq \sigma_{dov} = 8,5 \text{ MPa}$	VYHOVUJE

Deformace: $\delta = |1,24| \% \leq \delta_{dov} = 6 \%$ **VYHOVUJE**

Ztráta stability: $\lambda_{krit} = |13,23| \geq \lambda_{dov} = 2$ **VYHOVUJE**

Název akce:	Ústí nad Orlicí - Perla 01
Firma:	M Projekt CZ, s.r.o.
Vypracoval:	
Datum:	1.2.2019

Trubka

Typ trubky: (PP) SN 16

Označení průměru trubky DN: 200 mm

Vnější průměr trubky: 223,6 mm

Vnitřní průměr trubky: 196,4 mm

Řez stěnou



Podmínky uložení

Výška krytí zeminy nad potrubím: 1,5 m

Hladina podzemní vody nad vrcholem: 1 m

Šířka výkopu: 1,2 m

Úhel sklonu výkopu: 90°

Způsob pokládky: Pokládka do otevřeného výkopu

Způsob uložení potrubí a provedení zásypu: A4B4

Zemní prostředí

Okolní rostlá zemina: G1

Stupeň zhutnění (Standard Proctor) S_{pr}: 90 %

Obsypová zemina (v zóně potrubí): G1

Stupeň zhutnění (Standard Proctor) S_{pr}: 90 %

Zásypová zemina (nad zónou potrubí): G1

Stupeň zhutnění (Standard Proctor) S_{pr}: 90 %

Zatížení


Zatížení dopravou: Vozidlo - SLW30 (DIN)

Rovnoměrné plošné zatížení: 0 kN/m²

Tento výpočet je proveden dle ATV-DVWK-A 127: 2000 a nenahrazuje
oficiální statické posouzení provedené autorizovaným statikem.

Název akce: Ústí nad Orlicí - Perla 01
 Firma: M Projekt CZ, s.r.o.
 Vypracoval:
 Datum: 1.2.2019

Zemní profil



Posouzení

Napětí:

Vrchol trubky - vnější povrch: $ \sigma_{v,e} = -3,84 \text{ MPa} \leq \sigma_{dov} = 8,5 \text{ MPa}$	VYHOVUJE
Vrchol trubky - vnitřní povrch: $ \sigma_{v,i} = 0,99 \text{ MPa} \leq \sigma_{dov} = 8,5 \text{ MPa}$	VYHOVUJE
Bok trubky - vnější povrch: $ \sigma_{b,e} = 1,68 \text{ MPa} \leq \sigma_{dov} = 8,5 \text{ MPa}$	VYHOVUJE
Bok trubky - vnitřní povrch: $ \sigma_{b,i} = -1,87 \text{ MPa} \leq \sigma_{dov} = 8,5 \text{ MPa}$	VYHOVUJE
Pata trubky - vnější povrch: $ \sigma_{p,e} = -4,72 \text{ MPa} \leq \sigma_{dov} = 8,5 \text{ MPa}$	VYHOVUJE
Pata trubky - vnitřní povrch: $ \sigma_{p,i} = 1,35 \text{ MPa} \leq \sigma_{dov} = 8,5 \text{ MPa}$	VYHOVUJE

Deformace: $\delta = |1,24| \% \leq \delta_{dov} = 6 \%$ **VYHOVUJE**

Ztráta stability: $\lambda_{krit} = |9,17| \geq \lambda_{dov} = 2$ **VYHOVUJE**

Název akce:	Ústí nad Orlicí - Perla 01
Firma:	M Projekt CZ, s.r.o.
Vypracoval:	
Datum:	1.2.2019

Trubka

Typ trubky: (PP) SN 16

Označení průměru trubky DN: 200 mm

Vnější průměr trubky: 223,6 mm

Vnitřní průměr trubky: 196,4 mm

Řez stěnou



Podmínky uložení

Výška krytí zeminy nad potrubím: 1,5 m

Hladina podzemní vody nad vrcholem: 1,5 m

Šířka výkopu: 1,2 m

Úhel sklonu výkopu: 90°

Způsob pokládky: Pokládka do otevřeného výkopu

Způsob uložení potrubí a provedení zásypu: A4B4

Zemní prostředí

Okolní rostlá zemina: G1

Stupeň zhutnění (Standard Proctor) S_{pr}: 90 %

Obsypová zemina (v zóně potrubí): G1

Stupeň zhutnění (Standard Proctor) S_{pr}: 90 %

Zásypová zemina (nad zónou potrubí): G1

Stupeň zhutnění (Standard Proctor) S_{pr}: 90 %

Zatížení


Zatížení dopravou: Vozidlo - SLW30 (DIN)

Rovnoměrné plošné zatížení: 0 kN/m²

Tento výpočet je proveden dle ATV-DVWK-A 127: 2000 a nenahrazuje oficiální statické posouzení provedené autorizovaným statikem.

Název akce:	Ústí nad Orlicí - Perla 01
Firma:	M Projekt CZ, s.r.o.
Vypracoval:	
Datum:	1.2.2019

Zemní profil



Posouzení

Napětí:

Vrchol trubky - vnější povrch: $ \sigma_{v,e} = -3,84 \text{ MPa} \leq \sigma_{dov} = 8,5 \text{ MPa}$	VYHOVUJE
Vrchol trubky - vnitřní povrch: $ \sigma_{v,i} = 0,99 \text{ MPa} \leq \sigma_{dov} = 8,5 \text{ MPa}$	VYHOVUJE
Bok trubky - vnější povrch: $ \sigma_{b,e} = 1,68 \text{ MPa} \leq \sigma_{dov} = 8,5 \text{ MPa}$	VYHOVUJE
Bok trubky - vnitřní povrch: $ \sigma_{b,i} = -1,87 \text{ MPa} \leq \sigma_{dov} = 8,5 \text{ MPa}$	VYHOVUJE
Pata trubky - vnější povrch: $ \sigma_{p,e} = -4,72 \text{ MPa} \leq \sigma_{dov} = 8,5 \text{ MPa}$	VYHOVUJE
Pata trubky - vnitřní povrch: $ \sigma_{p,i} = 1,35 \text{ MPa} \leq \sigma_{dov} = 8,5 \text{ MPa}$	VYHOVUJE

Deformace: $\delta = |1,24| \% \leq \delta_{dov} = 6 \%$ **VYHOVUJE**

Ztráta stability: $\lambda_{krit} = |7,02| \geq \lambda_{dov} = 2$ **VYHOVUJE**

Název akce:	Ústí nad Orlicí - Perla 01
Firma:	M Projekt CZ, s.r.o.
Vypracoval:	
Datum:	1.2.2019

Trubka

Typ trubky: (PP) SN 16

Označení průměru trubky DN: 200 mm

Vnější průměr trubky: 223,6 mm

Vnitřní průměr trubky: 196,4 mm

Řez stěnou



Podmínky uložení

Výška krytí zeminy nad potrubím: 2 m

Hladina podzemní vody nad vrcholem: 2 m

Šířka výkopu: 1,2 m

Úhel sklonu výkopu: 90°

Způsob pokládky: Pokládka do otevřeného výkopu

Způsob uložení potrubí a provedení zásypu: A4B4

Zemní prostředí

Okolní rostlá zemina: G1

Stupeň zhutnění (Standard Proctor) S_{pr}: 90 %

Obsypová zemina (v zóně potrubí): G1

Stupeň zhutnění (Standard Proctor) S_{pr}: 90 %

Zásypová zemina (nad zónou potrubí): G1

Stupeň zhutnění (Standard Proctor) S_{pr}: 90 %

Zatížení


Zatížení dopravou: Vozidlo - SLW30 (DIN)

Rovnoměrné plošné zatížení: 0 kN/m²

Tento výpočet je proveden dle ATV-DVWK-A 127: 2000 a nenahrazuje oficiální statické posouzení provedené autorizovaným statikem.

Název akce:	Ústí nad Orlicí - Perla 01
Firma:	M Projekt CZ, s.r.o.
Vypracoval:	
Datum:	1.2.2019

Zemní profil



Posouzení

Napětí:

Vrchol trubky - vnější povrch: $ \sigma_{v,e} = -3,27 \text{ MPa}$	$\leq \sigma_{dov} = 8,5 \text{ MPa}$	VYHOVUJE
Vrchol trubky - vnitřní povrch: $ \sigma_{v,i} = 0,73 \text{ MPa}$	$\leq \sigma_{dov} = 8,5 \text{ MPa}$	VYHOVUJE
Bok trubky - vnější povrch: $ \sigma_{b,e} = 1,2 \text{ MPa}$	$\leq \sigma_{dov} = 8,5 \text{ MPa}$	VYHOVUJE
Bok trubky - vnitřní povrch: $ \sigma_{b,i} = -1,6 \text{ MPa}$	$\leq \sigma_{dov} = 8,5 \text{ MPa}$	VYHOVUJE
Pata trubky - vnější povrch: $ \sigma_{p,e} = -4,11 \text{ MPa}$	$\leq \sigma_{dov} = 8,5 \text{ MPa}$	VYHOVUJE
Pata trubky - vnitřní povrch: $ \sigma_{p,i} = 1,07 \text{ MPa}$	$\leq \sigma_{dov} = 8,5 \text{ MPa}$	VYHOVUJE

Deformace: $\delta = |1,16| \% \leq \delta_{dov} = 6 \%$ **VYHOVUJE**

Ztráta stability: $\lambda_{krit} = |5,68| \geq \lambda_{dov} = 2$ **VYHOVUJE**

Název akce: Ústí nad Orlicí - Perla 01
Firma: M Projekt CZ, s.r.o.
Výpracoval:
Datum: 1.2.2019

Trubka

Typ trubky: (PP) SN 16

Označení průměru trubky DN: 200 mm

Vnější průměr trubky: 223,6 mm

Vnitřní průměr trubky: 196,4 mm

Řez stěnou



Podmínky uložení

Výška krytí zeminy nad potrubím: 2 m

Hladina podzemní vody nad vrcholem: 0 m

Šířka výkopu: 1,2 m

Úhel sklonu výkopu: 90°

Způsob pokládky: Pokládka do otevřeného výkopu

Způsob uložení potrubí a provedení zásypu: A4B4

Zemní prostředí

Okolní rostlá zemina: G1

Stupeň zhutnění (Standard Proctor) S_{pr}: 90 %

Obsypová zemina (v zóně potrubí): G1

Stupeň zhutnění (Standard Proctor) S_{pr}: 90 %

Zásypová zemina (nad zónou potrubí): G1

Stupeň zhutnění (Standard Proctor) S_{pr}: 90 %

Zatížení


Zatížení dopravou: Vozidlo - SLW30 (DIN)

Rovnoměrné plošné zatížení: 0 kN/m²

Tento výpočet je proveden dle ATV-DVWK-A 127: 2000 a nenahrazuje oficiální statické posouzení provedené autorizovaným statikem.

Název akce:	Ústí nad Orlicí - Perla 01
Firma:	M Projekt CZ, s.r.o.
Vypracoval:	
Datum:	1.2.2019

Zemní profil



Posouzení

Napětí:

Vrchol trubky - vnější povrch: $ \sigma_{v,e} = -3,27 \text{ MPa} \leq \sigma_{dov} = 8,5 \text{ MPa}$	VYHOVUJE
Vrchol trubky - vnitřní povrch: $ \sigma_{v,i} = 0,73 \text{ MPa} \leq \sigma_{dov} = 8,5 \text{ MPa}$	VYHOVUJE
Bok trubky - vnější povrch: $ \sigma_{b,e} = 1,2 \text{ MPa} \leq \sigma_{dov} = 8,5 \text{ MPa}$	VYHOVUJE
Bok trubky - vnitřní povrch: $ \sigma_{b,i} = -1,6 \text{ MPa} \leq \sigma_{dov} = 8,5 \text{ MPa}$	VYHOVUJE
Pata trubky - vnější povrch: $ \sigma_{p,e} = -4,11 \text{ MPa} \leq \sigma_{dov} = 8,5 \text{ MPa}$	VYHOVUJE
Pata trubky - vnitřní povrch: $ \sigma_{p,i} = 1,07 \text{ MPa} \leq \sigma_{dov} = 8,5 \text{ MPa}$	VYHOVUJE

Deformace: $\delta = |1,16| \% \leq \delta_{dov} = 6 \%$ **VYHOVUJE**

Ztráta stability: $\lambda_{krit} = |18,55| \geq \lambda_{dov} = 2$ **VYHOVUJE**

Název akce: Ústí nad Orlicí - Perla 01
Firma: M Projekt CZ, s.r.o.
Vypracoval:
Datum: 1.2.2019

Trubka

Typ trubky: (PP) SN 16

Označení průměru trubky DN: 200 mm

Vnější průměr trubky: 223,6 mm

Vnitřní průměr trubky: 196,4 mm

Řez stěnou



Podmínky uložení

Výška krytí zeminy nad potrubím: 2,5 m

Hladina podzemní vody nad vrcholem: 0 m

Šířka výkopu: 1,2 m

Úhel sklonu výkopu: 90°

Způsob pokládky: Pokládka do otevřeného výkopu

Způsob uložení potrubí a provedení zásypu: A4B4

Zemní prostředí

Okolní rostlá zemina: G1

Stupeň zhutnění (Standard Proctor) S_{pr}: 90 %

Obsypová zemina (v zóně potrubí): G1

Stupeň zhutnění (Standard Proctor) S_{pr}: 90 %

Zásypová zemina (nad zónou potrubí): G1

Stupeň zhutnění (Standard Proctor) S_{pr}: 90 %

Zatížení


Zatížení dopravou: Vozidlo - SLW30 (DIN)

Rovnoměrné plošné zatížení: 0 kN/m²

Tento výpočet je proveden dle ATV-DVWK-A 127: 2000 a nenahrazuje oficiální statické posouzení provedené autorizovaným statikem.

Název akce:	Ústí nad Orlicí - Perla 01
Firma:	M Projekt CZ, s.r.o.
Vypracoval:	
Datum:	1.2.2019

Zemní profil



Posouzení

Napětí:

Vrchol trubky - vnější povrch: $ \sigma_{v,e} = -2,91 \text{ MPa} \leq \sigma_{dov} = 8,5 \text{ MPa}$	VYHOVUJE
Vrchol trubky - vnitřní povrch: $ \sigma_{v,i} = 0,56 \text{ MPa} \leq \sigma_{dov} = 8,5 \text{ MPa}$	VYHOVUJE
Bok trubky - vnější povrch: $ \sigma_{b,e} = 0,9 \text{ MPa} \leq \sigma_{dov} = 8,5 \text{ MPa}$	VYHOVUJE
Bok trubky - vnitřní povrch: $ \sigma_{b,i} = -1,44 \text{ MPa} \leq \sigma_{dov} = 8,5 \text{ MPa}$	VYHOVUJE
Pata trubky - vnější povrch: $ \sigma_{p,e} = -3,74 \text{ MPa} \leq \sigma_{dov} = 8,5 \text{ MPa}$	VYHOVUJE
Pata trubky - vnitřní povrch: $ \sigma_{p,i} = 0,89 \text{ MPa} \leq \sigma_{dov} = 8,5 \text{ MPa}$	VYHOVUJE

Deformace: $\delta = |1,12| \% \leq \delta_{dov} = 6 \%$ **VYHOVUJE**

Ztráta stability: $\lambda_{krit} = |18,03| \geq \lambda_{dov} = 2$ **VYHOVUJE**

ŽEBROVANÉ POTRUBÍ
PP D280/DN250
SN10, SN16

Zadávací podmínky

Použité potrubí: **Stl 10, DN 250**

Krytí nad vrcholem potrubí: 1,5 m

Zatížení: D 400

Hladina spodní vody: 0,5 m pod úrovní terénu

Obsypový materiál: písek, štěrkopísek, lomová prosíčka 0-8 mm

Stupeň zhutnění obsypu: 95 %PS

Result

Calculation OK

Given values			
Pipe type		Pipe dimension (mm)	250
Soil type	Sand		
Safety class	Normal	Control class	Normal
Partial coefficient - safety class	2.27	Partial coefficient - control class	1.50
Max. negative pressure in pipe (kPa)	Compression class Normal > 95% SP		
Installation type	Normal trench and normal up to high compaction	Installation factor %	1.0 %
Bedding/bedding layer	Normal levelling layer	Bedding factor %	2.00 %
Traffic load	Heavy traffic load	Max. negative pressure in pipe (kPa)	0.00
Soil cover above pipe top (m) = H	1.50	Distance from ground level to ground-water level (m) = Hw	0.50
Relative density - below ground-water level (kN/m³)	10.00	Relative density - above ground-water level (kN/m³)	20.00
Calculated diameter of pipe (mm)	250.00	Pipe ring stiffness	10.00
Load combination 1.1 Deformation calculation serviceability limit state			
Average stress from traffic load (qtm) kN/m²	30.25	Short-term deformation from variable load (traffic)	0.8 %
Load factor C regarding the stiffness ratio of pipe to backfilling material (applied)	1.00	Short-term deformation from permanent load (soil)	0.9 %
Characteristic traffic load qtk kN/m² (Formula 9)	30.25	Deformation from installation (Table 2.9)	1.0 %
Additional soil cover for determination of soil modulus E <td>1.37</td> <td>Average deformation</td> <td>2.7 %</td>	1.37	Average deformation	2.7 %
delta H factor dependent on type of road traffic load	1.0	Short-term maximum deformation (Page 42)	4.7 %
Tangent modulus of backfill above ground-water E <td>4355</td> <td>Long-term deformation from load (formula 16)</td> <td>2.5 %</td>	4355	Long-term deformation from load (formula 16)	2.5 %
Secant modulus of backfill above ground-water	2831	Long-term max.	6.4 %

E_{ad} (Formula 12) - kN/m ²		deformation (Formula 15)
Reduction factor for ground-water influence on soil E-moduli (formula 13)	0.73	
Tangent modulus of backfill below ground-water E_{td} (Formula 11 x Formula 13) - kN/m ²	3193	
Secant modulus of backfill below ground-water E_{sd} (Formula 12 x Formula 13) - kN/m ²	2076	

Short-term maximum deformation (Page 42) 4.7 % < 9.0 % (Pipematerial: PP) - OK

Load deformation 2.1 Deformation calculation ultimate limit state			
Calculated ring stiffness (kN/m ²)	5.33	Calculated max. buckling pressure (kN/m ²)	489.84
Calculated tangent modulus (kN/m ²)	1409.31	Design load (kN/m ²)	70.57
Reduction factor beta	0.81	Design buckling pressure (kN/m ²)	396.21

Buckling load combination 2.1 - σ_a (Formula 20) kN/m² 70.57 < Buckling load combination 2.1 - G_{xg} (Formula 22) 396.21 - OK

Při dodržení zadávacích podmínek a zhutnění obsypu na 95% PS potrubí SN 10, DN 250 vyhoví a jeho deformace nepřesáhne hodnotu 4,7 %.

Zadávací podmínky

Použité potrubí: SN 10, DN 250

Krytí nad vrcholem potrubí: 1,5 m

Zatížení: D 400

Hladina spodní vody: 1 m pod úrovní terénu

Obsypový materiál: písek, štěrkoplísek, lomová prosívka 0-8 mm

Stupeň zhutnění obsypu: 95 %PS

Result

Calculation OK

Given values			
Pipe type		Pipe dimension (mm)	250
Soil type	Sand		
Safety class	Normal	Control class	Normal
Partial coefficient - safety class	2.27	Partial coefficient - control class	1.50
Max. negative pressure in pipe (kPa)	Compression class Normal > 95% SP		
Installation type	Normal trench and normal up to high compaction	Installation factor %	1.0 %
Bedding/bedding layer	Normal levelling layer	Bedding factor %	2.00 %
Traffic load	Heavy traffic load	Max. negative pressure in pipe (kPa)	0.00
Soil cover above pipe top (m) = H	1.50	Distance from ground level to ground-water level (m) = Hw	1.00
Relative density - below ground-water level (kN/m³)	10.00	Relative density - above ground-water level (kN/m³)	20.00
Calculated diameter of pipe (mm)	250.00	Pipe ring stiffness	10.00
Load combination 1.1 Deformation calculation serviceability limit state			
Average stress from traffic load (qtm) kN/m²	30.25	Short-term deformation from variable load (traffic)	0.7 %
Load factor C regarding the stiffness ratio of pipe to backfilling material (applied)	1.00	Short-term deformation from permanent load (soil)	0.8 %
Characteristic traffic load qtk kN/m² (Formula 9)	30.25	Deformation from installation (Table 2.9)	1.0 %
Additional soil cover for determination of soil modulus E _{sd} when influenced by heavy road traffic load (Table 2.8)	1.37	Average deformation	2.5 %
delta H factor dependent on type of road traffic load	1.0	Short-term maximum deformation (Page 42)	4.5 %
Tangent modulus of backfill above ground-water E _{sd} (Formula 11) - kN/m²	4355	Long-term deformation from load (formula 16)	2.2 %
Secant modulus of backfill above ground-water E _{sd} (Formula 12) - kN/m²	2831	Long-term max. deformation (Formula 15)	6.0 %

Reduction factor for ground-water influence on
soil E-moduli (formula 13) 0.87

Tangent modulus of backfill below ground-water
 E_{ed} (Formula 11 x Formula 13) - kN/m² 3774

Secant modulus of backfill below ground-water
 E_{sd} (Formula 12 x Formula 13) - kN/m² 2453

Short-term maximum deformation (Page 42) 4.5 % < 9.0 % (Pipe material; PP) - OK

Load deformation 2.1 Deformation calculation ultimate limit state

Calculated ring stiffness (kN/m ²)	5.33	Calculated max. buckling pressure (kN/m ²)	532.51
Calculated tangent modulus (kN/m ²)	1665.55	Design load (kN/m ²)	70.57
Reduction factor beta	0.82	Design buckling pressure (kN/m ²)	436.86

Buckling load combination 2.1 - q_a (Formula 20) kN/m² 70.57 < Buckling load combination 2.1 - $\beta \times q_b$ (Formula 22) 436.86 - OK

Při dodržení zadávacích podmínek a zhutnění obsypu na 95% PS
potrubí SN 10, DN 250 vyhoví a jeho deformace
nepřesáhne hodnotu 4,5 %.

Zadávací podmínky

Použité potrubí: SN 10, DN 250

Krytí nad vrcholem potrubí: 1,5 m

Zatížení: D 400

Hladina spodní vody: 1,5 m pod úrovni terénu

Obsypový materiál: písek, štěrkopísek, lomová prosívka 0-8 mm

Stupeň zhutnění obsypu: 95 %PS

Result

Calculation OK

Given values			
Pipe type		Pipe dimension (mm)	250
Soil type	Sand		
Safety class	Normal	Control class	Normal
Partial coefficient - safety class	2.27	Partial coefficient - control class	1.50
Max. negative pressure in pipe (kPa)	Compression class Normal > 95% SP		
Installation type	Normal trench and normal up to high compaction	Installation factor %	1.0 %
Bedding/bedding layer	Normal levelling layer	Bedding factor %	2.00 %
Traffic load	Heavy traffic load	Max. negative pressure in pipe (kPa)	0.00
Soil cover above pipe top (m) = H	1.50	Distance from ground level to ground-water level (m) = Hw	1.50
Relative density - below ground-water level (kN/m³)	10.00	Relative density - above ground-water level (kN/m³)	20.00
Calculated diameter of pipe (mm)	250.00	Pipe ring stiffness	10.00
Load combination 1.1 Deformation calculation serviceability limit state			
Average stress from traffic load (qtm) kN/m²	30.25	Short-term deformation from variable load (traffic)	0.7 %
Load factor C regarding the stiffness ratio of pipe to backfilling material (applied)	1.00	Short-term deformation from permanent load (soil)	0.7 %
Characteristic traffic load qtk kN/m² (Formula 9)	30.25	Deformation from Installation (Table 2.9)	1.0 %
Additional soil cover for determination of soil modulus E _{sd} when influenced by heavy road traffic load (Table 2.8)	1.37	Average deformation	2.3 %
delta H factor dependent on type of road traffic load	1.0	Short-term maximum deformation (Page 42)	4.3 %
Tangent modulus of backfill above ground-water E _{sd} (Formula 11) - kN/m²	4355	Long-term deformation from load (formula 16)	2.0 %
Secant modulus of backfill above ground-water E _{sd} (Formula 12) - kN/m²	2831	Long-term max. deformation (Formula 15)	5.7 %
Reduction factor for ground-water influence on	1.00		

soil E-moduli (formula 13)

Tangent modulus of backfill below ground-water 4355
 E_{sd} (Formula 11 x Formula 13) - kN/m²

Secant modulus of backfill below ground-water 2831
 E_{sd} (Formula 12 x Formula 13) - kN/m²

Short-term maximum deformation (Page 42) 4.3 % < 9.0 % (Pipematerial: PP) - OK

Load deformation 2.1 Deformation calculation ultimate limit state

Calculated ring stiffness (kN/m²)	5.33	Calculated max. buckling pressure (kN/m²)	572.01
Calculated tangent modulus (kN/m²)	1921.79	Design load (kN/m²)	70.57
Reduction factor beta	0.83	Design buckling pressure (kN/m²)	474.51

Buckling load combination 2.1 - q_a (Formula 20) kN/m² 70.57 < Buckling load combination 2.1 - $\beta \times q_b$ (Formula 22) 474.51 - OK

Při dodržení zadávacích podmínek a zhutnění obsypu na 95% PS
potrubí SN 10, DN 250 vyhoví a jeho deformace
nepřesáhne hodnotu 4,3 %.

Zadávací podmínky

Použité potrubí: SN 10, DN 250

Krytí nad vrcholem potrubí: 1,5 m

Zatížení: D 400

Hladina spodní vody: 2 m pod úrovní terénu

Obsypový materiál: písek, štěrkopísek, lomová prosíkva 0-8 mm

Stupeň zhutnění obsypu: 95 %PS

Result

Calculation OK

<u>Given values</u>			
Pipe type		Pipe dimension (mm)	250
Soil type	Sand		
Safety class	Normal	Control class	Normal
Partial coefficient - safety class	2.27	Partial coefficient - control class	1.50
Max. negative pressure in pipe (kPa)	Compression class Normal > 95% SP		
Installation type	Normal trench and normal up to high compaction	Installation factor %	1.0 %
Bedding/bedding layer	Normal levelling layer	Bedding factor %	2.00 %
Traffic load	Heavy traffic load	Max. negative pressure in pipe (kPa)	0.00
Soil cover above pipe top (m) = H	1.50	Distance from ground level to ground-water level (m) = Hw	2.00
Relative density - below ground-water level (kN/m³)	10.00	Relative density - above ground-water level (kN/m³)	20.00
Calculated diameter of pipe (mm)	250.00	Pipe ring stiffness	10.00
<u>Load combination 1.1 Deformation calculation serviceability limit state</u>			
Average stress from traffic load (qtm) kN/m²	30.25	Short-term deformation from variable load (traffic)	0.6 %
Load factor C regarding the stiffness ratio of pipe to backfilling material (applied)	1.00	Short-term deformation from permanent load (soil)	0.6 %
Characteristic traffic load qtk kN/m² (Formula 9)	30.25	Deformation from installation (Table 2.9)	1.0 %
Additional soil cover for determination of soil modulus E_{sd} when influenced by heavy road traffic load (Table 2.8)	1.37	Average deformation	2.2 %
delta H factor dependent on type of road traffic load	1.0	Short-term maximum deformation (Page 42)	4.2 %
Tangent modulus of backfill above ground-water E_{sd} (Formula 11) - kN/m²	4355	Long-term deformation from load (formula 16)	1.8 %
Secant modulus of backfill above ground-water E_{sd} (Formula 12) - kN/m²	2831	Long-term max. deformation (Formula 15)	5.4 %
Reduction factor for ground-water influence on soil E-moduli (formula 13)	1.13		

Tangent modulus of backfill below ground-water 4935
 E_{td} (Formula 11 x Formula 13) - kN/m²

Secant modulus of backfill below ground-water 3208
 E_{sd} (Formula 12 x Formula 13) - kN/m²

Short-term maximum deformation (Page 42) 4,2 % < 9,0 % (Pipematerial: PP) - OK

Load deformation 2.1 Deformation calculation ultimate limit state			
Calculated ring stiffness (kN/m ²)	5.33	Calculated max. buckling pressure (kN/m ²)	572.01
Calculated tangent modulus (kN/m ²)	2178.03	Design load (kN/m ²)	79.32
Reduction factor beta	0.84	Design buckling pressure (kN/m ²)	478.77

Buckling load combination 2.1 - q_4 (Formula 20) kN/m² 79.32 < Buckling load combination 2.1 - $G \times q_2$ (Formula 22) 478.77 - OK

Při dodržení zadávacích podmínek a zhutnění obsypu na 95% PS potrubí SN 10, DN 250 vyhoví a jeho deformace nepřesáhne hodnotu 4,2 %.

Zadávací podmínky

Použité potrubí: SN 10, DN 250

Krytí nad vrcholem potrubí: 1,5 m

Zatížení: D 400

Hladina spodní vody: 3 m pod úrovní terénu

Obsypový materiál: písek, štěrkopísek, lomová prosíkva 0-8 mm

Stupeň zhutnění obsypu: 95 %PS

Result

Calculation OK

Given values			
Pipe type		Pipe dimension (mm)	250
Soil type	Sand		
Safety class	Normal	Control class	Normal
Partial coefficient - safety class	2.27	Partial coefficient - control class	1.50
Max. negative pressure in pipe (kPa)	Compression class Normal > 95% SP		
Installation type	Normal trench and normal up to high compaction	Installation factor %	1.0 %
Bedding/bedding layer	Normal levelling layer	Bedding factor %	2.00 %
Traffic load	Heavy traffic load	Max. negative pressure in pipe (kPa)	0.00
Soil cover above pipe top (m) = H	1.50	Distance from ground level to ground-water level (m) = 3.00 Hw	
Relative density - below ground-water level (kN/m³)	10.00	Relative density - above ground-water level (kN/m³)	20.00
Calculated diameter of pipe (mm)	250.00	Pipe ring stiffness	10.00
Load combination 1.1 Deformation calculation serviceability limit state			
Average stress from traffic load (qtm) kN/m²	30.25	Short-term deformation from variable load (traffic)	0.5 %
Load factor C regarding the stiffness ratio of pipe to backfilling material (applied)	1.00	Short-term deformation from permanent load (soil)	0.5 %
Characteristic traffic load qtk kN/m² (Formula 9)	30.25	Deformation from installation (Table 2.9)	1.0 %
Additional soil cover for determination of soil modulus E_d when influenced by heavy road traffic load (Table 2.8)	1.37	Average deformation	2.0 %
delta H factor dependent on type of road traffic load	1.0	Short-term maximum deformation (Page 42)	4.0 %
Tangent modulus of backfill above ground-water E _{td} (Formula 11) - kN/m²	4355	Long-term deformation from load (formula 16)	1.5 %
Secant modulus of backfill above ground-water E _{sd} (Formula 12) - kN/m²	2831	Long-term max. deformation (Formula 15)	5.1 %
Reduction factor for ground-water influence on	1.40		

soil E-modul (formula 13)

Tangent modulus of backfill below ground-water E_{td} (Formula 11 x Formula 13) - kN/m² 6097

Secant modulus of backfill below ground-water E_{sd} (Formula 12 x Formula 13) - kN/m² 3963

Short-term maximum deformation (Page 42) 4.0 % < 9.0 % (Pipematerial: PP) - OK

Load deformation 2.1 Deformation calculation ultimate limit state

Calculated ring stiffness (kN/m ²)	5.33	Calculated max. buckling pressure (kN/m ²)	572.01
Calculated tangent modulus (kN/m ²)	2690.50	Design load (kN/m ²)	99.32
Reduction factor beta	0.85	Design buckling pressure (kN/m ²)	485.30

Buckling load combination 2.1 - q_d (Formula 20) 99.32 < Buckling load combination 2.1 - $\delta \times q_b$ (Formula 22) 485.30 - OK

**Při dodržení zadávacích podmínek a zhutnění obsypu na 95% PS
potrubí SN 10, DN 250 vyhoví a jeho deformace
nepřesáhne hodnotu 4,0 %.**

Zadávací podmínky

Použité potrubí: SN 10, DN 250

Krytí nad vrcholem potrubí: 1,5 m

Zatížení: D 400

Hladina spodní vody: bez výskytu spodní vody

Obsypový materiál: písek, štěrkopísek, lomová prosíkva 0-8 mm

Stupeň zhutnění obsypu: 95 %PS

Result

Calculation OK

Given values

Pipe type		Pipe dimension (mm)	250
Soil type	Sand		
Safety class	Normal	Control class	Normal
Partial coefficient - safety class	2.27	Partial coefficient - control class	1.50
Max. negative pressure in pipe (kPa)	Compression class Normal > 95% SP		
Installation type	Normal trench and normal up to high compaction	Installation factor %	1.0 %
Bedding/bedding layer	Normal levelling layer	Bedding factor %	2.00 %
Traffic load	Heavy traffic load	Max. negative pressure In pipe (kPa)	0.00
Soil cover above pipe top (m) = H	1.50	Distance from ground level to ground-water level (m) = 5.00 Hw	
Relative density - below ground-water level (kN/m³)	10.00	Relative density - above ground-water level (kN/m³)	20.00
Calculated diameter of pipe (mm)	250.00	Pipe ring stiffness	10.00

Load combination 1.1 Deformation calculation serviceability limit state

Average stress from traffic load (qtm) kN/m²	30.25	Short-term deformation from variable load (traffic)	0.4 %
Load factor C regarding the stiffness ratio of pipe to backfilling material (applied)	1.00	Short-term deformation from permanent load (soil)	0.4 %
Characteristic traffic load qtk kN/m² (Formula 9)	30.25	Deformation from installation (Table 2.9)	1.0 %
Additional soil cover for determination of soil modulus E_d when influenced by heavy road traffic load (Table 2.8)	1.37	Average deformation	1.8 %
delta H factor dependent on type of road traffic load	1.0	Short-term maximum deformation (Page 42)	3.8 %
Tangent modulus of backfill above ground-water E_{sd} (Formula 11) - kN/m²	4355	Long-term deformation from load (formula 16)	1.2 %
Secant modulus of backfill above ground-water E_{sd} (Formula 12) - kN/m²	2831	Long-term max. deformation (Formula 15)	4.6 %

Reduction factor for ground-water influence on
soil E-moduli (formula 13) 1.93

Tangent modulus of backfill below ground-water
 E_w (Formula 11 x Formula 13) - kN/m² 8419

Secant modulus of backfill below ground-water
 E_{sd} (Formula 12 x Formula 13) - kN/m² 5472

Short-term maximum deformation (Page 42) 3.8 % < 9.0 % (Pipematerial: PP) - OK

Load deformation 2.1 Deformation calculation ultimate limit state

Calculated ring stiffness (kN/m ²)	5.33	Calculated max. buckling pressure (kN/m ²)	572.01
Calculated tangent modulus (kN/m ²)	3715.46	Design load (kN/m ²)	139.32
Reduction factor beta	0.86	Design buckling pressure (kN/m ²)	493.69

Buckling load combination 2.1 - q_a (Formula 20) kN/m² 139.32 < Buckling load combination 2.1 - $8 \times q_b$ (Formula 22) 493.69 - OK

Při dodržení zadávacích podmínek a zhotvení obsypu na 95% PS
potrubí SN 10, DN 250 vyhoví a jeho deformace
nepřesáhne hodnotu 3,8 %.

Zadávací podmínky

Použité potrubí: SN 10, DN 250

Krytí nad vrcholem potrubí: 2,5 m

Zatížení: D 400

Hladina spodní vody: 2 m pod úrovní terénu

Obsypový materiál: písek, štěrkopísek, lomová prosívka 0-8 mm

Stupeň zhutnění obsypu: 95 %PS

Result

Calculation OK

Given values			
Pipe type		Pipe dimension (mm)	250
Soil type	Sand		
Safety class	Normal	Control class	Normal
Partial coefficient - safety class	2.27	Partial coefficient - control class	1.50
Max. negative pressure in pipe (kPa)	Compression class Normal > 95% SP		
Installation type	Normal trench and normal up to high compaction	Installation factor %	1.0 %
Bedding/bedding layer	Normal levelling layer	Bedding factor %	2.00 %
Traffic load	Heavy traffic load	Max. negative pressure in pipe (kPa)	0.00
Soil cover above pipe top (m) = H	2.50	Distance from ground level to ground-water level (m) = Hw	2.00
Relative density - below ground-water level (kN/m³)	10.00	Relative density - above ground-water level (kN/m³)	20.00
Calculated diameter of pipe (mm)	280.00	Pipe ring stiffness	10.00
Load combination 1.1 Deformation calculation serviceability limit state			
Average stress from traffic load (qtm) kN/m²	22.23	Short-term deformation from variable load (traffic)	0.4 %
Load factor C regarding the stiffness ratio of pipe to backfilling material (applied)	1.00	Short-term deformation from permanent load (soil)	1.1 %
Characteristic traffic load qtk kN/m² (Formula 9)	22.23	Deformation from installation (Table 2.9)	1.0 %
Additional soil cover for determination of soil modulus E _{sd} when influenced by heavy road traffic load (Table 2.8)	1.10	Average deformation	2.5 %
delta H factor dependent on type of road traffic load	1.0	Short-term maximum deformation (Page 42)	4.5 %

Tangent modulus of backfill above ground-water E_{td} (Formula 11) - kN/m ²	5052	Long-term deformation from load (formula 16)	2.3 %
Secant modulus of backfill above ground-water E_{sd} (Formula 12) - kN/m ²	3284	Long-term max. deformation (Formula 15)	6.1 %
Reduction factor for ground-water influence on soil E-moduli (formula 13)	0.93		
Tangent modulus of backfill below ground-water E_{td} (Formula 11 x Formula 13) - kN/m ²	4715		
Secant modulus of backfill below ground-water E_{sd} (Formula 12 x Formula 13) - kN/m ²	3065		

Short-term maximum deformation (Page 42) 4.5 % < 9.0 % (Pipematerial: PP) - OK

Load deformation 2.1 Deformation calculation ultimate limit state

Calculated ring stiffness (kN/m ²)	5.33	Calculated max. buckling pressure (kN/m ²)	595.19
Calculated tangent modulus (kN/m ²)	2080.71	Design load (kN/m ²)	80.15
Reduction factor beta	0.82	Design buckling pressure (kN/m ²)	486.85

Buckling load combination 2.1 - q_a (Formula 20) kN/m² 80.15 < Buckling load combination 2.1 - $0.6 \times q_b$ (Formula 22) 486.85 - OK

Při dodržení zadávacích podmínek a zhutnění obsypu na 95% PS potrubí SN 10, DN 250 vyhoví a jeho deformace nepřesáhne hodnotu 4,5 %.

Zadávací podmínky

Použité potrubí: SN 10, DN 250

Krytý nad vrcholem potrubí: 3,2 m

Zatížení provozem: D 400

Hladina spodní vody: 2 m pod úrovní terénu

Obsypový materiál: štěrkopísek, lomová drť 0-16

Stupeň zhutnění obsypu: 95 %PS

Result

Calculation OK

Given values			
Pipe type		Pipe dimension (mm)	250
Soil type	Sand		
Safety class	Normal	Control class	Normal
Partial coefficient - safety class	2.27	Partial coefficient - control class	1.50
Max. negative pressure in pipe (kPa)	Compression class Normal > 95% SP		
Installation type	Normal trench and normal up to high compaction	Installation factor %	1.0 %
Bedding/bedding layer	Normal levelling layer	Bedding factor %	2.00 %
Traffic load	Heavy traffic load	Max. negative pressure in pipe (kPa)	0.00
Soil cover above pipe top (m) = H	3.20	Distance from ground level to ground-water level (m) = Hw	2.00
Relative density - below ground-water level (kN/m³)	10.00	Relative density - above ground-water level (kN/m³)	20.00
Calculated diameter of pipe (mm)	250.00	Pipe ring stiffness	10.00
<u>Load combination 1.1 Deformation calculation serviceability limit state</u>			
Average stress from traffic load (qtm) kN/m²	17.38	Short-term deformation from variable load (traffic)	0.3 %
Load factor C regarding the stiffness ratio of pipe to backfilling material (applied)	1.00	Short-term deformation from permanent load (soil)	1.4 %
Characteristic traffic load qtk kN/m² (Formula 9)	17.38	Deformation from installation (Table 2.9)	1.0 %

Additional soil cover for determination of soil modulus E_{sd} when influenced by heavy road traffic load (Table 2.8)	0.88	Average deformation	2.7 %
delta H factor dependent on type of road traffic load	1.0	Short-term maximum deformation (Page 42)	<u>4.7 %</u>
Tangent modulus of backfill above ground-water E_{td} (Formula 11) - kN/m²	5693	Long-term deformation from load (formula 16)	2.6 %
Secant modulus of backfill above ground-water E_{sd} (Formula 12) - kN/m²	3700	Long-term max. deformation (Formula 15)	6.4 %
Reduction factor for ground-water influence on soil E-moduli (formula 13)	0.85		
Tangent modulus of backfill below ground-water E_{td} (Formula 11 x Formula 13) - kN/m²	4839		
Secant modulus of backfill below ground-water E_{sd} (Formula 12 x Formula 13) - kN/m²	3145		

Short-term maximum deformation (Page 42) 4.7 % < 9.0 % (Pipematerial: PP) - OK

Load deformation 2.1 Deformation calculation ultimate limit state			
Calculated ring stiffness (kN/m²)	5.33	Calculated max. buckling pressure (kN/m²)	602.96
Calculated tangent modulus (kN/m²)	2135.38	Design load (kN/m²)	87.85
Reduction factor beta	0.81	Design buckling pressure (kN/m²)	486.97

Buckling load combination 2.1 - q_d (Formula 20) kN/m² 87.85 < Buckling load combination 2.1 - $B \times q_u$ (Formula 22) 486.97 - OK

Při dodržení zadávacích podmínek potrubí vyhoví a jeho deformace nepřesáhne hodnotu 4,7 %.

SN 10, DN 250

Zadávací podmínky

Použité potrubí: SN 10, DN 250

Krytí nad vrcholem potrubí: 0,75 m

Zatížení provozem: D 400

Hladina spodní vody: 1,06 m pod úrovni terénu

Obsypový materiál: štěrkopísek, lomová drť 0-16

Stupeň zhutnění obsypu: 95 %PS

Result

Calculation OK

Given values			
Pipe type		Pipe dimension (mm)	250
Soil type	Sand		
Safety class	Normal	Control class	Normal
Partial coefficient - safety class	2.27	Partial coefficient - control class	1.50
Max. negative pressure in pipe (kPa)	Compression class Normal > 95% SP		
Installation type	Normal trench and normal up to high compaction	Installation factor %	1.0 %
Bedding/bedding layer	Normal levelling layer	Bedding factor %	2.00 %
Traffic load	Heavy traffic load	Max. negative pressure in pipe (kPa)	0.00
Soil cover above pipe top (m) = H	0.75	Distance from ground level to ground-water level (m) = Hw	1.06
Relative density - below ground-water level (kN/m³)	10.00	Relative density - above ground-water level (kN/m³)	20.00
Calculated diameter of pipe (mm)	250.00	Pipe ring stiffness	10.00
Load combination 1.1 Deformation calculation serviceability limit state			
Average stress from traffic load (qtm) kN/m²	81.29	Short-term deformation from variable load (traffic)	1.5 %
Load factor C regarding the stiffness ratio of pipe to backfilling material (applied)	1.00	Short-term deformation from permanent load (soil)	0.3 %
Characteristic traffic load qtk kN/m² (Formula 9)	81.29	Deformation from installation (Table 2.9)	1.0 %
Additional soil cover for determination of soil modulus E_d when influenced by heavy road traffic load (Table 2.8)	2.28	Average deformation	2.8 %
delta H factor dependent on type of road	1.0	Short-term maximum	4.8 %

traffic load		deformation (Page 42)	
Tangent modulus of backfill above ground-water E_{td} (Formula 11) - kN/m²	4475	Long-term deformation from load (formula 16)	2.6 %
Secant modulus of backfill above ground-water E_{sd} (Formula 12) - kN/m²	2909	Long-term max. deformation (Formula 15)	6.5 %
Reduction factor for ground-water influence on soil E-moduli (formula 13)	1.21		
Tangent modulus of backfill below ground-water E_{td} (Formula 11 x Formula 13) - kN/m²	5395		
Secant modulus of backfill below ground-water E_{sd} (Formula 12 x Formula 13) - kN/m²	3507		
<u>Short-term maximum deformation (Page 42) 4.8 % < 9.0 % f Pipematerial: PP) - OK</u>			
Load deformation 2.1 Deformation calculation ultimate limit state			
Calculated ring stiffness (kN/m²)	5.33	Calculated max. buckling pressure (kN/m²)	579.83
Calculated tangent modulus (kN/m²)	2380.93	Design load (kN/m²)	126.88
Reduction factor beta	0.80	Design buckling pressure (kN/m²)	466.44
<u>Buckling load combination 2.1 - q_d (Formula 20) kN/m² 126.88 < Buckling load combination 2.1 - Bxq_b (Formula 22) 466.44 - OK</u>			

Při dodržení zadávacích podmínek potrubí SN 10, DN 250 vyhoví a jeho deformace nepřesáhne hodnotu 4,8 %.

V těchto podmínkách potrubí obsypte nesoudržným materiélem (pískem nebo lomovou prosívkou 0-4) do úrovně 10 cm nad vrchol. Zbývající vrstvu o tloušťce cca 25 cm vytvořte z hrubšího materiálu frakce 32-63. Takto se vytvoří nad potrubím skladba, která odolá pojazdům běžné techniky při vytváření dalších vrstev vozovky a asfaltového povrchu.

Název akce:	Ústí nad Orlicí - Perla 01
Firma:	M Projekt CZ, s.r.o.
Vypracoval:	
Datum:	1.2.2019

Trubka

Typ trubky: (PP) SN 16

Označení průměru trubky DN: 250 mm

Vnější průměr trubky: 278,3 mm

Vnitřní průměr trubky: 245,3 mm

Řez stěnou



Podmínky uložení

Výška krytí zeminy nad potrubím: 1,5 m

Hladina podzemní vody nad vrcholem: 0,5 m

Šířka výkopu: 1,2 m

Úhel sklonu výkopu: 90°

Způsob pokládky: Pokládka do otevřeného výkopu

Způsob uložení potrubí a provedení zásypu: A4B4

Zemní prostředí

Okolní rostlá zemina: G1

Stupeň zhutnění (Standard Proctor) S_{pr}: 90 %

Obsypová zemina (v zóně potrubí): G1

Stupeň zhutnění (Standard Proctor) S_{pr}: 90 %

Zásypová zemina (nad zónou potrubí): G1

Stupeň zhutnění (Standard Proctor) S_{pr}: 90 %

Zatížení


Zatížení dopravou: Vozidlo - SLW30 (DIN)

Rovnoměrné plošné zatížení: 0 kN/m²

Tento výpočet je proveden dle ATV-DVWK-A 127: 2000 a nenahrazuje oficiální statické posouzení provedené autorizovaným statikem.

Název akce:	Ústí nad Orlicí - Perla 01
Firma:	M Projekt CZ, s.r.o.
Vypracoval:	
Datum:	1.2.2019

Zemní profil



Posouzení

Napětí:

Vrchol trubky - vnější povrch: $ \sigma_{v,e} = -3,72 \text{ MPa} \leq \sigma_{dov} = 8,5 \text{ MPa}$	VYHOVUJE
Vrchol trubky - vnitřní povrch: $ \sigma_{v,i} = 1 \text{ MPa} \leq \sigma_{dov} = 8,5 \text{ MPa}$	VYHOVUJE
Bok trubky - vnější povrch: $ \sigma_{b,e} = 1,53 \text{ MPa} \leq \sigma_{dov} = 8,5 \text{ MPa}$	VYHOVUJE
Bok trubky - vnitřní povrch: $ \sigma_{b,i} = -1,93 \text{ MPa} \leq \sigma_{dov} = 8,5 \text{ MPa}$	VYHOVUJE
Pata trubky - vnější povrch: $ \sigma_{p,e} = -4,59 \text{ MPa} \leq \sigma_{dov} = 8,5 \text{ MPa}$	VYHOVUJE
Pata trubky - vnitřní povrch: $ \sigma_{p,i} = 1,39 \text{ MPa} \leq \sigma_{dov} = 8,5 \text{ MPa}$	VYHOVUJE

Deformace: $\delta = |1,23| \% \leq \delta_{dov} = 6 \%$ **VYHOVUJE**

Ztráta stability: $\lambda_{krit} = |13,08| \geq \lambda_{dov} = 2$ **VYHOVUJE**

Název akce:	Ústí nad Orlicí - Perla 01
Firma:	M Projekt CZ, s.r.o.
Vypracoval:	
Datum:	1.2.2019

Trubka

Typ trubky: (PP) SN 16

Označení průměru trubky DN: 250 mm

Vnější průměr trubky: 278,3 mm

Vnitřní průměr trubky: 245,3 mm

Řez stěnou



Podmínky uložení

Výška krytí zeminy nad potrubím: 1,5 m

Hladina podzemní vody nad vrcholem: 0,5 m

Šířka výkopu: 1,2 m

Úhel sklonu výkopu: 90°

Způsob pokládky: Pokládka do otevřeného výkopu

Způsob uložení potrubí a provedení zásypu: A4B4

Zemní prostředí

Okolní rostlá zemina: G1

Stupeň zhutnění (Standard Proctor) S_{pr}: 90 %

Obsypová zemina (v zóně potrubí): G1

Stupeň zhutnění (Standard Proctor) S_{pr}: 90 %

Zásypová zemina (nad zónou potrubí): G1

Stupeň zhutnění (Standard Proctor) S_{pr}: 90 %

Zatížení


Zatížení dopravou: Vozidlo - SLW30 (DIN)

Rovnoměrné plošné zatížení: 0 kN/m²

Tento výpočet je proveden dle ATV-DVWK-A 127: 2000 a nenahrazuje oficiální statické posouzení provedené autorizovaným statikem.

Název akce:	Ústí nad Orlicí - Perla 01
Firma:	M Projekt CZ, s.r.o.
Vypracoval:	
Datum:	1.2.2019

Zemní profil



Posouzení

Napětí:

Vrchol trubky - vnější povrch: $ \sigma_{v,e} = -3,72 \text{ MPa} \leq \sigma_{dov} = 8,5 \text{ MPa}$	VYHOVUJE
Vrchol trubky - vnitřní povrch: $ \sigma_{v,i} = 1 \text{ MPa} \leq \sigma_{dov} = 8,5 \text{ MPa}$	VYHOVUJE
Bok trubky - vnější povrch: $ \sigma_{b,e} = 1,53 \text{ MPa} \leq \sigma_{dov} = 8,5 \text{ MPa}$	VYHOVUJE
Bok trubky - vnitřní povrch: $ \sigma_{b,i} = -1,93 \text{ MPa} \leq \sigma_{dov} = 8,5 \text{ MPa}$	VYHOVUJE
Pata trubky - vnější povrch: $ \sigma_{p,e} = -4,59 \text{ MPa} \leq \sigma_{dov} = 8,5 \text{ MPa}$	VYHOVUJE
Pata trubky - vnitřní povrch: $ \sigma_{p,i} = 1,39 \text{ MPa} \leq \sigma_{dov} = 8,5 \text{ MPa}$	VYHOVUJE

Deformace: $\delta = |1,23| \% \leq \delta_{dov} = 6 \%$ **VYHOVUJE**

Ztráta stability: $\lambda_{krit} = |13,08| \geq \lambda_{dov} = 2$ **VYHOVUJE**

Název akce:	Ústí nad Orlicí - Perla 01
Firma:	M Projekt CZ, s.r.o.
Vypracoval:	
Datum:	1.2.2019

Trubka

Typ trubky: (PP) SN 16

Označení průměru trubky DN: 250 mm

Vnější průměr trubky: 278,3 mm

Vnitřní průměr trubky: 245,3 mm

Řez stěnou



Podmínky uložení

Výška krytí zeminy nad potrubím: 1,5 m

Hladina podzemní vody nad vrcholem: 1,5 m

Šířka výkopu: 1,2 m

Úhel sklonu výkopu: 90°

Způsob pokládky: Pokládka do otevřeného výkopu

Způsob uložení potrubí a provedení zásypu: A4B4

Zemní prostředí

Okolní rostlá zemina: G1

Stupeň zhutnění (Standard Proctor) S_{pr}: 90 %

Obsypová zemina (v zóně potrubí): G1

Stupeň zhutnění (Standard Proctor) S_{pr}: 90 %

Zásypová zemina (nad zónou potrubí): G1

Stupeň zhutnění (Standard Proctor) S_{pr}: 90 %

Zatížení


Zatížení dopravou: Vozidlo - SLW30 (DIN)

Rovnoměrné plošné zatížení: 0 kN/m²

Tento výpočet je proveden dle ATV-DVWK-A 127: 2000 a nenahrazuje
oficiální statické posouzení provedené autorizovaným statikem.

Název akce:	Ústí nad Orlicí - Perla 01
Firma:	M Projekt CZ, s.r.o.
Vypracoval:	
Datum:	1.2.2019

Zemní profil



Posouzení

Napětí:

Vrchol trubky - vnější povrch: $ \sigma_{v,e} = -3,72 \text{ MPa} \leq \sigma_{dov} = 8,5 \text{ MPa}$	VYHOVUJE
Vrchol trubky - vnitřní povrch: $ \sigma_{v,i} = 1 \text{ MPa} \leq \sigma_{dov} = 8,5 \text{ MPa}$	VYHOVUJE
Bok trubky - vnější povrch: $ \sigma_{b,e} = 1,53 \text{ MPa} \leq \sigma_{dov} = 8,5 \text{ MPa}$	VYHOVUJE
Bok trubky - vnitřní povrch: $ \sigma_{b,i} = -1,93 \text{ MPa} \leq \sigma_{dov} = 8,5 \text{ MPa}$	VYHOVUJE
Pata trubky - vnější povrch: $ \sigma_{p,e} = -4,59 \text{ MPa} \leq \sigma_{dov} = 8,5 \text{ MPa}$	VYHOVUJE
Pata trubky - vnitřní povrch: $ \sigma_{p,i} = 1,39 \text{ MPa} \leq \sigma_{dov} = 8,5 \text{ MPa}$	VYHOVUJE

Deformace: $\delta = |1,23| \% \leq \delta_{dov} = 6 \%$ **VYHOVUJE**

Ztráta stability: $\lambda_{krit} = |6,93| \geq \lambda_{dov} = 2$ **VYHOVUJE**

Název akce:	Ústí nad Orlicí - Perla 01
Firma:	M Projekt CZ, s.r.o.
Vypracoval:	
Datum:	1.2.2019

Trubka

Typ trubky: (PP) SN 16

Označení průměru trubky DN: 250 mm

Vnější průměr trubky: 278,3 mm

Vnitřní průměr trubky: 245,3 mm

Řez stěnou



Podmínky uložení

Výška krytí zeminy nad potrubím: 2 m

Hladina podzemní vody nad vrcholem: 2 m

Šířka výkopu: 1,2 m

Úhel sklonu výkopu: 90°

Způsob pokládky: Pokládka do otevřeného výkopu

Způsob uložení potrubí a provedení zásypu: A4B4

Zemní prostředí

Okolní rostlá zemina: G1

Stupeň zhutnění (Standard Proctor) S_{pr}: 90 %

Obsypová zemina (v zóně potrubí): G1

Stupeň zhutnění (Standard Proctor) S_{pr}: 90 %

Zásypová zemina (nad zónou potrubí): G1

Stupeň zhutnění (Standard Proctor) S_{pr}: 90 %

Zatížení


Zatížení dopravou: Vozidlo - SLW30 (DIN)

Rovnoměrné plošné zatížení: 0 kN/m²

Tento výpočet je proveden dle ATV-DVWK-A 127: 2000 a nenahrazuje oficiální statické posouzení provedené autorizovaným statikem.

Název akce:	Ústí nad Orlicí - Perla 01
Firma:	M Projekt CZ, s.r.o.
Vypracoval:	
Datum:	1.2.2019

Zemní profil



Posouzení

Napětí:

Vrchol trubky - vnější povrch:	$ \sigma_{v,e} = -3,17 \text{ MPa} \leq \sigma_{dov} = 8,5 \text{ MPa}$	VYHOVUJE
Vrchol trubky - vnitřní povrch:	$ \sigma_{v,i} = 0,73 \text{ MPa} \leq \sigma_{dov} = 8,5 \text{ MPa}$	VYHOVUJE
Bok trubky - vnější povrch:	$ \sigma_{b,e} = 1,08 \text{ MPa} \leq \sigma_{dov} = 8,5 \text{ MPa}$	VYHOVUJE
Bok trubky - vnitřní povrch:	$ \sigma_{b,i} = -1,66 \text{ MPa} \leq \sigma_{dov} = 8,5 \text{ MPa}$	VYHOVUJE
Pata trubky - vnější povrch:	$ \sigma_{p,e} = -4,02 \text{ MPa} \leq \sigma_{dov} = 8,5 \text{ MPa}$	VYHOVUJE
Pata trubky - vnitřní povrch:	$ \sigma_{p,i} = 1,1 \text{ MPa} \leq \sigma_{dov} = 8,5 \text{ MPa}$	VYHOVUJE

Deformace: $\delta = |1,16| \% \leq \delta_{dov} = 6 \%$ **VYHOVUJE**

Ztráta stability: $\lambda_{krit} = |5,61| \geq \lambda_{dov} = 2$ **VYHOVUJE**

Název akce: Ústí nad Orlicí - Perla 01
Firma: M Projekt CZ, s.r.o.
Vypracoval:
Datum: 1.2.2019

Trubka

Typ trubky: (PP) SN 16

Označení průměru trubky DN: 250 mm

Vnější průměr trubky: 278,3 mm

Vnitřní průměr trubky: 245,3 mm

Řez stěnou



Podmínky uložení

Výška krytí zeminy nad potrubím: 2 m

Hladina podzemní vody nad vrcholem: 0 m

Šířka výkopu: 1,2 m

Úhel sklonu výkopu: 90°

Způsob pokládky: Pokládka do otevřeného výkopu

Způsob uložení potrubí a provedení zásypu: A4B4

Zemní prostředí

Okolní rostlá zemina: G1

Stupeň zhutnění (Standard Proctor) S_{pr}: 90 %

Obsypová zemina (v zóně potrubí): G1

Stupeň zhutnění (Standard Proctor) S_{pr}: 90 %

Zásypová zemina (nad zónou potrubí): G1

Stupeň zhutnění (Standard Proctor) S_{pr}: 90 %

Zatížení


Zatížení dopravou: Vozidlo - SLW30 (DIN)

Rovnoměrné plošné zatížení: 0 kN/m²

Tento výpočet je proveden dle ATV-DVWK-A 127: 2000 a nenahrazuje oficiální statické posouzení provedené autorizovaným statikem.

Název akce:	Ústí nad Orlicí - Perla 01
Firma:	M Projekt CZ, s.r.o.
Vypracoval:	
Datum:	1.2.2019

Zemní profil



Posouzení

Napětí:

Vrchol trubky - vnější povrch: $ \sigma_{v,e} = -3,17 \text{ MPa} \leq \sigma_{dov} = 8,5 \text{ MPa}$	VYHOVUJE
Vrchol trubky - vnitřní povrch: $ \sigma_{v,i} = 0,73 \text{ MPa} \leq \sigma_{dov} = 8,5 \text{ MPa}$	VYHOVUJE
Bok trubky - vnější povrch: $ \sigma_{b,e} = 1,08 \text{ MPa} \leq \sigma_{dov} = 8,5 \text{ MPa}$	VYHOVUJE
Bok trubky - vnitřní povrch: $ \sigma_{b,i} = -1,66 \text{ MPa} \leq \sigma_{dov} = 8,5 \text{ MPa}$	VYHOVUJE
Pata trubky - vnější povrch: $ \sigma_{p,e} = -4,02 \text{ MPa} \leq \sigma_{dov} = 8,5 \text{ MPa}$	VYHOVUJE
Pata trubky - vnitřní povrch: $ \sigma_{p,i} = 1,1 \text{ MPa} \leq \sigma_{dov} = 8,5 \text{ MPa}$	VYHOVUJE

Deformace: $\delta = |1,16| \% \leq \delta_{dov} = 6 \%$ **VYHOVUJE**

Ztráta stability: $\lambda_{krit} = |18,36| \geq \lambda_{dov} = 2$ **VYHOVUJE**

Název akce:	Ústí nad Orlicí - Perla 01
Firma:	M Projekt CZ, s.r.o.
Vypracoval:	
Datum:	1.2.2019

Trubka

Typ trubky: (PP) SN 16

Označení průměru trubky DN: 250 mm

Vnější průměr trubky: 278,3 mm

Vnitřní průměr trubky: 245,3 mm

Řez stěnou



Podmínky uložení

Výška krytí zeminy nad potrubím: 2,5 m

Hladina podzemní vody nad vrcholem: 0 m

Šířka výkopu: 1,2 m

Úhel sklonu výkopu: 90°

Způsob pokládky: Pokládka do otevřeného výkopu

Způsob uložení potrubí a provedení zásypu: A4B4

Zemní prostředí

Okolní rostlá zemina: G1

Stupeň zhutnění (Standard Proctor) S_{pr}: 90 %

Obsypová zemina (v zóně potrubí): G1

Stupeň zhutnění (Standard Proctor) S_{pr}: 90 %

Zásypová zemina (nad zónou potrubí): G1

Stupeň zhutnění (Standard Proctor) S_{pr}: 90 %

Zatížení


Zatížení dopravou: Vozidlo - SLW30 (DIN)

Rovnoměrné plošné zatížení: 0 kN/m²

Tento výpočet je proveden dle ATV-DVWK-A 127: 2000 a nenahrazuje
oficiální statické posouzení provedené autorizovaným statikem.

Název akce:	Ústí nad Orlicí - Perla 01
Firma:	M Projekt CZ, s.r.o.
Vypracoval:	
Datum:	1.2.2019

Zemní profil



Posouzení

Napětí:

Vrchol trubky - vnější povrch: $ \sigma_{v,e} = -2,83 \text{ MPa} \leq \sigma_{dov} = 8,5 \text{ MPa}$	VYHOVUJE
Vrchol trubky - vnitřní povrch: $ \sigma_{v,i} = 0,55 \text{ MPa} \leq \sigma_{dov} = 8,5 \text{ MPa}$	VYHOVUJE
Bok trubky - vnější povrch: $ \sigma_{b,e} = 0,79 \text{ MPa} \leq \sigma_{dov} = 8,5 \text{ MPa}$	VYHOVUJE
Bok trubky - vnitřní povrch: $ \sigma_{b,i} = -1,5 \text{ MPa} \leq \sigma_{dov} = 8,5 \text{ MPa}$	VYHOVUJE
Pata trubky - vnější povrch: $ \sigma_{p,e} = -3,65 \text{ MPa} \leq \sigma_{dov} = 8,5 \text{ MPa}$	VYHOVUJE
Pata trubky - vnitřní povrch: $ \sigma_{p,i} = 0,92 \text{ MPa} \leq \sigma_{dov} = 8,5 \text{ MPa}$	VYHOVUJE

Deformace: $\delta = |1,11| \% \leq \delta_{dov} = 6 \%$ **VYHOVUJE**

Ztráta stability: $\lambda_{krit} = |17,84| \geq \lambda_{dov} = 2$ **VYHOVUJE**

ŽEBROVANÉ POTRUBÍ
PP D335/DN300
SN10, SN16

Zadávací podmínky

Použité potrubí: SN 10, DN 300

Krytí nad vrcholem potrubí: 0,8 m

Zatížení provozem: D 400

Hladina spodní vody: 0,7 m pod úrovní terénu

Obsypový materiál: štěrkopísek, lomová prosíčka 0-8 mm

Stupeň zhutnění obsypu: 95 %PS

Result

Calculation OK

<u>Given values</u>			
Pipe type		Pipe dimension (mm)	335
Soil type	Sand		
Safety class	Normal	Control class	Normal
Partial coefficient - safety class	2.27	Partial coefficient - control class	1.50
Max. negative pressure in pipe (kPa)	Compression class Normal > 95% SP		
Installation type	Normal trench and normal up to high compaction	Installation factor %	1.0 %
Bedding/bedding layer	Normal levelling layer	Bedding factor %	2.00 %
Traffic load	Heavy traffic load	Max. negative pressure in pipe (kPa)	0.00
Soil cover above pipe top (m) = H	0.80	Distance from ground level to ground-water level (m) = Hw	0.70
Relative density - below ground-water level (kN/m³)	10.00	Relative density - above ground-water level (kN/m³)	20.00
Calculated diameter of pipe (mm)	335.00	Pipe ring stiffness	10.00
<u>Load combination 1.1 Deformation calculation serviceability limit state</u>			
Average stress from traffic load (qtm) kN/m²	61.93	Short-term deformation from variable load (traffic)	1.6 %
Load factor C regarding the stiffness ratio of pipe to backfilling material (applied)	1.00	Short-term deformation from permanent load (soil)	0.4 %

Characteristic traffic load qtk kN/m² (Formula 9)	61.93	Deformation from installation (Table 2.9)	1.0 %
Additional soil cover for determination of soil modulus E_{td} when influenced by heavy road traffic load (Table 2.8)	1.54	Average deformation	3.0 %
delta H factor dependent on type of road traffic load	1.0	Short-term maximum deformation (Page 42)	<u>5.0 %</u>
Tangent modulus of backfill above ground- water E_w (Formula 11) - kN/m²	3777	Long-term deformation from load (formula 16)	3.0 %
Secant modulus of backfill above ground- water E_{sd} (Formula 12) - kN/m²	2455	Long-term max. deformation (Formula 15)	6.9 %
Reduction factor for ground-water influence on soil E-moduli (formula 13)	0.95		
Tangent modulus of backfill below ground- water E_w (Formula 11 x Formula 13) - kN/m²	3588		
Secant modulus of backfill below ground- water E_{sd} (Formula 12 x Formula 13) - kN/m²	2332		

Short-term maximum deformation (Page 42) 5.0 % < 9.0 % (Pipematerial: PP) - OK

Load deformation 2.1 Deformation calculation ultimate limit state			
Calculated ring stiffness (kN/m²)	5.33	Calculated max. buckling pressure (kN/m²)	519.22
Calculated tangent modulus (kN/m²)	1583.46	Design load (kN/m²)	98.09
Reduction factor beta	0.79	Design buckling pressure (kN/m²)	410.99

**Buckling load combination 2.1 - q_d (Formula 20) kN/m² 98.09 < Buckling load combination
2.1 - Bxq_b (Formula 22) 410.99 - OK**

Při dodržení zadávacích podmínek potrubí SN 10, DN 300 vyhoví a jeho deformace nepřesáhne hodnotu 5,0%.

Zadávací podmínky

Použité potrubí: SN 10, DN 300

Krytí nad vrcholem potrubí: 0,8 m

Zatížení: D 400

Hladina spodní vody: 2 m pod úrovní terénu

Obsypový materiál: štěrkopísek, lomová prosívka 0-8 mm

Stupeň zhutnění obsypu: 95 %PS

Result

Calculation OK

Given values			
Pipe type		Pipe dimension (mm)	335
Soil type	Sand		
Safety class	Normal	Control class	Normal
Partial coefficient - safety class	2.27	Partial coefficient - control class	1.50
Max. negative pressure in pipe (kPa)	Compression class Normal > 95% SP		
Installation type	Normal trench and normal up to high compaction	Installation factor %	1.0 %
Bedding/bedding layer	Normal levelling layer	Bedding factor %	2.00 %
Traffic load	Heavy traffic load	Max. negative pressure in pipe (kPa)	0.00
Soil cover above pipe top (m) = H	0.80	Distance from ground level to ground-water level (m) = Hw	2.00
Relative density - below ground-water level (kN/m³)	10.00	Relative density - above ground-water level (kN/m³)	20.00
Calculated diameter of pipe (mm)	315.00	Pipe ring stiffness	10.00
Load combination 1.1 Deformation calculation serviceability limit state			
Average stress from traffic load (qtm) kN/m²	61.93	Short-term deformation from variable load (traffic)	1.0 %
Load factor C regarding the stiffness ratio of pipe to backfilling material (applied)	1.00	Short-term deformation from permanent load (soil)	0.3 %

Characteristic traffic load q_{tk} kN/m² (Formula 9)	61.93	Deformation from installation (Table 2.9)	1.0 %
Additional soil cover for determination of soil modulus E_m when influenced by heavy road traffic load (Table 2.8)	1.54	Average deformation	2.3 %
delta H factor dependent on type of road traffic load	1.0	Short-term maximum deformation (Page 42)	<u>4.3 %</u>
Tangent modulus of backfill above ground-water E_{td} (Formula 11) - kN/m²	3777	Long-term deformation from load (formula 16)	2.0 %
Secant modulus of backfill above ground-water E_{sd} (Formula 12) - kN/m²	2455	Long-term max. deformation (Formula 15)	5.6 %
Reduction factor for ground-water influence on soil E-moduli (formula 13)	1.60		
Tangent modulus of backfill below ground-water E_{td} (Formula 11 x Formula 13) - kN/m²	6043		
Secant modulus of backfill below ground-water E_{sd} (Formula 12 x Formula 13) - kN/m²	3928		

Short-term maximum deformation (Page 42) 4.3 % < 9.0 % (Pipematerial: PP) - OK

Load deformation 2.1 Deformation calculation ultimate limit state			
Calculated ring stiffness (kN/m²)	5.33	Calculated max. buckling pressure (kN/m²)	532.71
Calculated tangent modulus (kN/m²)	2666.88	Design load (kN/m²)	120.51
Reduction factor beta	0.83	Design buckling pressure (kN/m²)	443.17

Buckling load combination 2.1 - q_d (Formula 20) kN/m² 120.51 < Buckling load combination 2.1 - Bxq_b (Formula 22) 443.17 - OK

Při dodržení zadávacích podmínek potrubí SN 10, DN 300 vyhoví a jeho deformace nepřesáhne hodnotu 4,3%.

V úseku s takto malým krytím doporučujeme, potrubí obsypat nesoudržným materiélem (piskem nebo lomovou prosívkou 0-4) do úrovně 10 cm nad vrchol. Další vrstvu o tloušťce 20 cm vytvořte z hrubšího materiálu frakce 0-32 nebo ještě hrubšího. Takto se vytvoří nad potrubím skladba, která odolá pojedzdu běžné techniky.

Zadávací podmínky

Použité potrubí: SN 10, DN 300

Krytí nad vrcholem potrubí: 2,0 m

Zatížení: D 400

Hladina spodní vody: bez výskytu spodní vody

Obsypový materiál: písek, štěrkopísek, lomová prosíčka 0-8 mm

Stupeň zhutnění obsypu: 95 %PS

Result

Calculation OK

Given values

Pipe type		Pipe dimension (mm)	300
Soil type	Sand		
Safety class	Normal	Control class	Normal
Partial coefficient - safety class	2.27	Partial coefficient - control class	1.50
Max. negative pressure in pipe (kPa)	Compression class Normal > 95% SP		
Installation type	Normal trench and normal up to high compaction	Installation factor %	1.0 %
Bedding/bedding layer	Normal levelling layer	Bedding factor %	2.00 %
Traffic load	Heavy traffic load	Max. negative pressure in pipe (kPa)	0.00
Soil cover above pipe top (m) = H	2.00	Distance from ground level to ground-water level (m) = H_w	5.00
Relative density - below ground-water level (kN/m³)	10.00	Relative density - above ground-water level (kN/m³)	20.00
Calculated diameter of pipe (mm)	335.00	Pipe ring stiffness	10.00

Load combination 1.1 Deformation calculation serviceability limit state

Average stress from traffic load (qtm) kN/m²	24.64	Short-term deformation from variable load (traffic)	0.3 %
Load factor C regarding the stiffness ratio of pipe to backfilling material (applied)	1.00	Short-term deformation from permanent load (soil)	0.6 %
Characteristic traffic load qtk kN/m² (Formula 9)	24.64	Deformation from installation (Table 2.9)	1.0 %
Additional soil cover for determination of soil modulus E_d when influenced by heavy road traffic load (Table 2.8)	1.13	Average deformation	1.9 %
delta H factor dependent on type of road traffic load	1.0	Short-term maximum deformation (Page 42)	3.9 %
Tangent modulus of backfill above ground-water	4646	Long-term deformation	1.4 %

E_m (Formula 11) - kN/m ²		from load (formula 16)
Secant modulus of backfill above ground-water	3020	
E_{sd} (Formula 12) - kN/m ²		Long-term max. deformation (Formula 15) 4.9 %
Reduction factor for ground-water influence on soil E-moduli (formula 13)	1.60	
Tangent modulus of backfill below ground-water	7433	
E_m (Formula 11 x Formula 13) - kN/m ²		
Secant modulus of backfill below ground-water	4831	
E_{sd} (Formula 12 x Formula 13) - kN/m ²		

Short-term maximum deformation (Page 42) 3.9 % < 9.0 % (Pipematerial; PP) - OK

Load deformation 2.1 Deformation calculation ultimate limit state

Calculated ring stiffness (kN/m²)	5.33	Calculated max. buckling pressure (kN/m²)	590.79
Calculated tangent modulus (kN/m²)	3280.17	Design load (kN/m²)	132.04
Reduction factor beta	0.85	Design buckling pressure (kN/m²)	504.12

**Buckling load combination 2.1 - q_a (Formula 20) 132.04 < Buckling load combination 2.1 - $8 \times q_b$
(Formula 22) 504.12 - OK**

Při dodržení zadávacích podmínek a zhutnění obsypu na 95% PS
potrubí SN 10, DN 300 vyhoví a jeho deformace
nepřesáhne hodnotu 3,9 %.

Zadávací podmínky

Použité potrubí: SN 10, DN 300

Krytí nad vrcholem potrubí: 2,0 m

Zatížení: D 400

Hladina spodní vody: 0,7 m pod úrovni terénu

Obsypový materiál: písek, štěrkopísek, lomová prosíkva 0-8 mm

Stupeň zhutnění obsypu: 95 %PS

Result

Calculation OK

<u>Given values</u>			
Pipe type		Pipe dimension (mm)	300
Soil type	Sand		
Safety class	Normal	Control class	Normal
Partial coefficient - safety class	2.27	Partial coefficient - control class	1.50
Max. negative pressure in pipe (kPa)	Compression class Normal > 95% SP		
Installation type	Normal trench and normal up to high compaction	Installation factor %	1.0 %
Bedding/bedding layer	Normal levelling layer	Bedding factor %	2.00 %
Traffic load	Heavy traffic load	Max. negative pressure in pipe (kPa)	0.00
Soil cover above pipe top (m) = H	2.00	Distance from ground level to ground-water level (m) = Hw	0.70
Relative density - below ground-water level (kN/m³)	10.00	Relative density - above ground-water level (kN/m³)	20.00
Calculated diameter of pipe (mm)	335.00	Pipe ring stiffness	10.00
<u>Load combination 1.1 Deformation calculation serviceability limit state</u>			
Average stress from traffic load (qtm) kN/m²	24.64	Short-term deformation from variable load (traffic)	0.6 %
Load factor C regarding the stiffness ratio of pipe to backfilling material (applied)	1.00	Short-term deformation from permanent load (soil)	1.1 %
Characteristic traffic load qtk kN/m² (Formula 9)	24.64	Deformation from installation (Table 2.9)	1.0 %
Additional soil cover for determination of soil modulus E₄ when influenced by heavy road traffic load (Table 2.8)	1.13	Average deformation	2.7 %
delta H factor dependent on type of road traffic load	1.0	Short-term maximum deformation (Page 42)	4.7 %
Tangent modulus of backfill above ground-water	4646	Long-term deformation	2.6 %

E_{ad} (Formula 11) - kN/m ²		from load (formula 16)
Secant modulus of backfill above ground-water E_{ad} (Formula 12) - kN/m ²	3020	Long-term max. deformation (Formula 15) 6.5 %
Reduction factor for ground-water influence on soil E-moduli (formula 13)	0.74	
Tangent modulus of backfill below ground-water E_{ad} (Formula 11 x Formula 13) - kN/m ²	3438	
Secant modulus of backfill below ground-water E_{ad} (Formula 12 x Formula 13) - kN/m ²	2235	

Short-term maximum deformation (Page 42) 4.7 % < 9.0 % (Pipematerial: PP) - OK

Load deformation 2.1 Deformation calculation ultimate limit state

Calculated ring stiffness (kN/m ²)	5.33	Calculated max. buckling pressure (kN/m ²)	508.22
Calculated tangent modulus (kN/m ²)	1517.08	Design load (kN/m ²)	73.61
Reduction factor beta	0.81	Design buckling pressure (kN/m ²)	409.84

Buckling load combination 2.1 - q_u (Formula 20) kN/m² 73.61 < Buckling load combination 2.1 - $\delta \times q_u$,
(Formula 22) 409.84 - OK

Při dodržení zadávacích podmínek a zhutnění obsypu na 95% PS
potrubí SN 10, DN 300 vyhoví a jeho deformace
nepřesáhne hodnotu 4,7 %.

Zadávací podmínky

Použité potrubí: SN 10, DN 300

Krytí nad vrcholem potrubí: 2,0 m

Zatlžení: D 400

Hladina spodní vody: 1 m pod úrovní terénu

Obsypový materiál: písek, štěrkopísek, lomová prosíčka 0-8 mm

Stupeň zhutnění obsypy: 95 %PS

Result

Calculation OK

Pipe designation Uponor Ultra Rib 2 sewer system

Homepage: www.uponor.dk

Calculations of this program shall always be subject to an engineering examination prior to use. Uponor A/S and the program designers undertake no responsibility of whatsoever nature for errors or defects arising as a result of the use of the program.

Given values

Pipe type	Pipe dimension (mm)	315	
Soil type	Sand		
Safety class	Normal	Control class	Normal
Partial coefficient - safety class	2.27	Partial coefficient - control class	1.50
Max. negative pressure in pipe (kPa)	Compression class Normal > 95% SP		
Installation type	Normal trench and normal up to high compaction	Installation factor %	1.0 %
Bedding/bedding layer	Normal levelling layer	Bedding factor %	2.00 %
Traffic load	Heavy traffic load	Max. negative pressure in pipe (kPa)	0.00
Soil cover above pipe top (m) = H	2.00	Distance from ground level to ground-water level (m) = Hw	1.00
Relative density - below ground-water level (kN/m³)	10.00	Relative density - above ground- water level (kN/m³)	20.00
Calculated diameter of pipe (mm)	315.00	Pipe ring stiffness	8.00

Load combination 1.1 Deformation calculation serviceability limit state

Average stress from traffic load (qtm) kN/m²	24.64	Short-term deformation from variable load (traffic)	0.6 %
Load factor C regarding the stiffness ratio of pipe to backfilling material (applied)	1.00	Short-term deformation from permanent load (soil)	1.0 %
Characteristic traffic load qtk kN/m² (Formula 9)	24.64	Deformation from Installation (Table 2.9)	1.0 %
Additional soil cover for determination of soil modulus E _{soil} when influenced by heavy road traffic load (Table 2.8)	1.13	Average deformation	2.6 %
delta H factor dependent on type of road	1.0	Short-term maximum	4.6 %

traffic load		deformation (Page 42)	
Tangent modulus of backfill above ground-water E_{td} (Formula 11) - kN/m ²	4646	Long-term deformation from load (formula 16)	2.4 %
Secant modulus of backfill above ground-water E_{sd} (Formula 12) - kN/m ²	3020	Long-term max. deformation (Formula 15)	6.3 %
Reduction factor for ground-water influence on soil E-moduli (formula 13)	0.80		
Tangent modulus of backfill below ground-water E_{td} (Formula 11 x Formula 13) - kN/m ²	3716		
Secant modulus of backfill below ground-water E_{sd} (Formula 12 x Formula 13) - kN/m ²	2416		

Short-term maximum deformation (Page 42) 4.6 % < 9.0 % (Pipematerial: PP) - OK

Load deformation 2.1 Deformation calculation ultimate limit state

Calculated ring stiffness (kN/m ²)	5.33	Calculated max. buckling pressure (kN/m ²)	528.42
Calculated tangent modulus (kN/m ²)	1640.09	Design load (kN/m ²)	73.61
Reduction factor beta	0.81	Design buckling pressure (kN/m ²)	429.12

Buckling load combination 2.1 - q_a (Formula 20) kN/m² 73.61 < Buckling load combination 2.1 - $\beta \times q_a$ (Formula 22) 429.12 - OK

Při dodržení zadávacích podmínek a zhutnění obsypu na 95% PS potrubí SN 10, DN 300 vyhoví a jeho deformace nepřesáhne hodnotu 4,6 %.

Zadávací podmínky

Použité potrubí: SN 10, DN 300

Krytí nad vrcholem potrubí: 2,0 m

Zatížení: D 400

Hladina spodní vody: 1,6 m pod úrovní terénu

Obsypový materiál: písek, štěrkopísek, lomová prosíčka 0-8 mm

Stupeň zhutnění obsypu: 95 %PS

Result

Calculation OK

<u>Given values</u>			
Pipe type		Pipe dimension (mm)	315
Soil type	Sand		
Safety class	Normal	Control class	Normal
Partial coefficient - safety class	2.27	Partial coefficient - control class	1.50
Max. negative pressure in pipe (kPa)	Compression class Normal > 95% SP		
Installation type	Normal trench and normal up to high compaction	Installation factor %	1.0 %
Bedding/bedding layer	Normal levelling layer	Bedding factor %	2.00 %
Traffic load	Heavy traffic load	Max. negative pressure in pipe (kPa)	0.00
Soil cover above pipe top (m) = H	2.00	Distance from ground level to ground-water level (m) = L	1.60 Hw
Relative density - below ground-water level (kN/m³)	10.00	Relative density - above ground-water level (kN/m³)	20.00
Calculated diameter of pipe (mm)	315.00	Pipe ring stiffness	10.00
<u>Load combination 1.1 Deformation calculation serviceability limit state</u>			
Average stress from traffic load (qtm) kN/m²	24.64	Short-term deformation from variable load (traffic)	0.5 %
Load factor C regarding the stiffness ratio of pipe to backfilling material (applied)	1.00	Short-term deformation from permanent load (soil)	0.9 %
Characteristic traffic load qtk kN/m² (Formula 9)	24.64	Deformation from installation (Table 2.9)	1.0 %
Additional soil cover for determination of soil modulus E_d when influenced by heavy road traffic load (Table 2.8)	1.13	Average deformation	2.5 %
delta H factor dependent on type of road traffic load	1.0	Short-term maximum deformation (Page 42)	4.5 %

Tangent modulus of backfill above ground-water E_{ed} (Formula 11) - kN/m ²	4646	Long-term deformation from load (formula 16)	2.2 %
Secant modulus of backfill above ground-water E_{sd} (Formula 12) - kN/m ²	3020	Long-term max. deformation (Formula 15)	5.9 %
Reduction factor for ground-water influence on soil E-moduli (formula 13)	0.92		
Tangent modulus of backfill below ground-water E_{ed} (Formula 11 x Formula 13) - kN/m ²	4274		
Secant modulus of backfill below ground-water E_{sd} (Formula 12 x Formula 13) - kN/m ²	2778		

Short-term maximum deformation (Page 42) 4.5 % < 9.0 % (Pipematerial: PP) - OK

Load deformation 2.1 Deformation calculation ultimate limit state

Calculated ring stiffness (kN/m ²)	5.33	Calculated max. buckling pressure (kN/m ²)	566.67
Calculated tangent modulus (kN/m ²)	1886.10	Design load (kN/m ²)	73.61
Reduction factor beta	0.82	Design buckling pressure (kN/m ²)	465.64

Buckling load combination 2.1 - q_a (Formula 20) kN/m² 73.61 < Buckling load combination 2.1 - $\delta \times q_b$ (Formula 22) 465.64 - OK

Při dodržení zadávacích podmínek a zhutnění obsypu na 95% PS potrubí SN 10, DN 300 vyhoví a jeho deformace nepřesáhne hodnotu 4,5 %.

Zadávací podmínky

Použité potrubí: SN 10, DN 300

Krytí nad vrcholem potrubí: 2,0 m

Zatížení: D 400

Hladina spodní vody: 2 m pod úrovní terénu

Obsypový materiál: písek, štěrkopísek, lomová prosívka 0-8 mm

Stupeň zhutnění obsypu: 95 %PS

Result

Calculation OK

<u>Given values</u>			
Pipe type		Pipe dimension (mm)	315
Soil type	Sand		
Safety class	Normal	Control class	Normal
Partial coefficient - safety class	2.27	Partial coefficient - control class	1.50
Max. negative pressure in pipe (kPa)	Compression class Normal > 95% SP		
Installation type	Normal trench and normal up to high compaction	Installation factor %	1.0 %
Bedding/bedding layer	Normal levelling layer	Bedding factor %	2.00 %
Traffic load	Heavy traffic load	Max. negative pressure in pipe (kPa)	0.00
Soil cover above pipe top (m) = H	2.00	Distance from ground level to ground-water level (m) = Hw	
Relative density - below ground-water level (kN/m³)	10.00	Relative density - above ground-water level (kN/m³)	20.00
Calculated diameter of pipe (mm)	315.00	Pipe ring stiffness	10.00
<u>Load combination 1.1. Deformation calculation serviceability (limit state)</u>			
Average stress from traffic load (qtm) kN/m²	24.64	Short-term deformation from variable load (traffic)	0.5 %
Load factor C regarding the stiffness ratio of pipe to backfilling material (applied)	1.00	Short-term deformation from permanent load (soil)	0.9 %
Characteristic traffic load qtk kN/m² (Formula 9)	24.64	Deformation from installation (Table 2.9)	1.0 %
Additional soil cover for determination of soil modulus E _{soil} when influenced by heavy road traffic load (Table 2.8)	1.13	Average deformation	2.4 %
delta H factor dependent on type of road traffic load	1.0	Short-term maximum deformation (Page 42)	4.4 %
Tangent modulus of backfill above ground-water E _{sd} (Formula 11) - kN/m³	4646	Long-term deformation from load (formula 16)	2.1 %

Secant modulus of backfill above ground-water E_{sd} (Formula 12) - kN/m ²	3020	Long-term max. deformation (Formula 15)	5.8 %
Reduction factor for ground-water influence on soil E-moduli (formula 13)	1.00		
Tangent modulus of backfill below ground-water E_{td} (Formula 11 x Formula 13) - kN/m ²	4646		
Secant modulus of backfill below ground-water E_{sd} (Formula 12 x Formula 13) - kN/m ²	3020		

Short-term maximum deformation (Page 42) 4.4 % < 9.0 % (Pipematerial: PP) - OK

Load deformation 2.1 Deformation calculation ultimate limit state

Calculated ring stiffness (kN/m ²)	5.33	Calculated max. buckling pressure (kN/m ²)	590.79
Calculated tangent modulus (kN/m ²)	2050.11	Design load (kN/m ²)	73.61
Reduction factor beta	0.83	Design buckling pressure (kN/m ²)	488.67

Buckling load combination 2.1 - q_u (Formula 20) kN/m² 73.61 < Buckling load combination 2.1 - σ_{bxu}
(Formula 22) 488.67 - OK

Při dodržení zadávacích podmínek a zhutnění obsypu na 95% PS
potrubí SN 10, DN 300 vyhoví a jeho deformace
nepřesáhne hodnotu 4,4 %.

Zadávací podmínky

Použité potrubí: SN 10, DN 300

Krytí nad vrcholem potrubí: 2,0 m

Zatížení: D 400

Hladina spodní vody: 2,5 m pod úrovní terénu

Obsypový materiál: písek, štěrkopísek, lomová prosíkva 0-8 mm

Stupeň zhutnění obsypu: 95 %PS

Result

Calculation OK

Given values

Pipe type		Pipe dimension (mm)	315
Soil type	Sand		
Safety class	Normal	Control class	Normal
Partial coefficient - safety class	2.27	Partial coefficient - control class	1.50
Max. negative pressure in pipe (kPa)	Compression class Normal > 95% SP		
Installation type	Normal trench and normal up to high compaction	Installation factor %	1.0 %
Bedding/bedding layer	Normal levelling layer	Bedding factor %	2.00 %
Traffic load	Heavy traffic load	Max. negative pressure in pipe (kPa)	0.00
Soil cover above pipe top (m) = H	2.00	Distance from ground level to ground-water level (m) = Hw	2.50
Relative density - below ground-water level (kN/m³)	10.00	Relative density - above ground-water level (kN/m³)	20.00
Calculated diameter of pipe (mm)	315.00	Pipe ring stiffness	10.00

Load combination 1.1 Deformation calculation serviceability limit state

Average stress from traffic load (qtm) kN/m²	24.64	Short-term deformation from variable load (traffic)	0.5 %
Load factor C regarding the stiffness ratio of pipe to backfilling material (applied)	1.00	Short-term deformation from permanent load (soil)	0.8 %
Characteristic traffic load qtk kN/m² (Formula 9)	24.64	Deformation from installation (Table 2.9)	1.0 %

Additional soil cover for determination of soil modulus E_{td} when influenced by heavy road traffic load (Table 2.8)	1.13	Average deformation	2.3 %
delta H factor dependent on type of road traffic load	1.0	Short-term maximum deformation (Page 42)	4.3 %
Tangent modulus of backfill above ground-water E_{td} (Formula 11) - kN/m²	4646	Long-term deformation from load (formula 16)	1.9 %
Secant modulus of backfill above ground-water E_{sd} (Formula 12) - kN/m²	3020	Long-term max. deformation (Formula 15)	5.6 %
Reduction factor for ground-water influence on soil E-moduli (formula 13)	1.10		
Tangent modulus of backfill below ground-water E_{td} (Formula 11 x Formula 13) - kN/m²	5110		
Secant modulus of backfill below ground-water E_{sd} (Formula 12 x Formula 13) - kN/m²	3322		

Short-term maximum deformation (Page 42) 4.3 % < 9.0 % (Pipematerial: PP) - OK

Load deformation 2.1 Deformation calculation ultimate limit state

Calculated ring stiffness (kN/m²)	5.33	Calculated max. buckling pressure (kN/m²)	590.79
Calculated tangent modulus (kN/m²)	2255.12	Design load (kN/m²)	82.04
Reduction factor beta	0.83	Design buckling pressure (kN/m²)	492.17

Buckling load combination 2.1 - q_d (Formula 20) kN/m² 82.04 < Buckling load combination 2.1 - $\beta x q_b$ (Formula 22) 492.17 - OK

Při dodržení zadávacích podmínek a zhotvení obrysů na 95% PS potrubí SN 10, DN 300 vyhoví a jeho deformace nepřesáhne hodnotu 4,3 %.

Zadávací podmínky

Použité potrubí: SN 10, DN 300

Krytí nad vrcholem potrubí: 2,0 m

Zatížení: D 400

Hladina spodní vody: 3 m

Obsypový materiál: písek, štěrkopísek, lomová prosíčka 0-8 mm

Stupeň zhutnění obsypu: 95 %PS

Result

Calculation OK

Given values			
Pipe type		Pipe dimension (mm)	300
Soil type	Sand		
Safety class	Normal	Control class	Normal
Partial coefficient - safety class	2.27	Partial coefficient - control class	1.50
Max. negative pressure in pipe (kPa)	Compression class Normal > 95% SP		
Installation type	Normal trench and normal up to high compaction	Installation factor %	1.0 %
Bedding/bedding layer	Normal levelling layer	Bedding factor %	2.00 %
Traffic load	Heavy traffic load	Max. negative pressure in pipe (kPa)	0.00
Soil cover above pipe top (m) = H	2.00	Distance from ground level to ground-water level (m) = Hw	3.00
Relative density - below ground-water level (kN/m³)	10.00	Relative density - above ground-water level (kN/m³)	20.00
Calculated diameter of pipe (mm)	335.00	Pipe ring stiffness	10.00
Load combination 1.1 Deformation calculation serviceability limit state			
Average stress from traffic load (qtm) kN/m²	24.64	Short-term deformation from variable load (traffic)	0.4 %
Load factor C regarding the stiffness ratio of pipe to backfilling material (applied)	1.00	Short-term deformation from permanent load (soil)	0.8 %
Characteristic traffic load qtk kN/m² (Formula 9)	24.64	Deformation from installation (Table 2.9)	1.0 %
Additional soil cover for determination of soil modulus E _d when influenced by heavy road traffic load (Table 2.8)	1.13	Average deformation	2.2 %
delta H factor dependent on type of road traffic load	1.0	Short-term maximum deformation (Page 42)	4.2 %
Tangent modulus of backfill above ground-water E _d (Formula 11) - kN/m²	4646	Long-term deformation from load (formula 16)	1.8 %

Secant modulus of backfill above ground-water E_{sd} (Formula 12) - kN/m ²	3020	Long-term max. deformation (Formula 15)	5.4 %
Reduction factor for ground-water influence on soil E-moduli (formula 13)	1.20		
Tangent modulus of backfill below ground-water E_{td} (Formula 11 x Formula 13) - kN/m ²	5575		
Secant modulus of backfill below ground-water E_{sd} (Formula 12 x Formula 13) - kN/m ²	3624		

Short-term maximum deformation (Page 42) 4.2 % < 9.0 % (Pipematerial: PP) - OK

Load deformation 2.1 Deformation calculation ultimate limit state

Calculated ring stiffness (kN/m ²)	5.33	Calculated max. buckling pressure (kN/m ²)	590.79
Calculated tangent modulus (kN/m ²)	2460.13	Design load (kN/m ²)	92.04
Reduction factor beta	0.84	Design buckling pressure (kN/m ²)	495.19

Buckling load combination 2.1 - a_d (Formula 20) kN/m² 92.04 < Buckling load combination 2.1 - Gxq_b
(Formula 22) 495.19 - OK

Při dodržení zadávacích podmínek a zhutnění obsypu na 95% PS
potrubí SN 10, DN 300 vyhoví a jeho deformace
nepřesáhne hodnotu 4,2 %.

Zadávací podmínky

Použité potrubí: SN 10, DN 300

Krytí nad vrcholem potrubí: 3,2 m

Zatížení provozem: D 400

Hladina spodní vody: 2,5 m pod úrovní terénu

Obsypový materiál: štěrkopisek, lomová drť 0-16

Stupeň zhutnění obsypu: 95 %PS

Result

Calculation OK

Given values			
Pipe type		Pipe dimension (mm)	335
Soil type	Sand		
Safety class	Normal	Control class	Normal
Partial coefficient - safety class	2.27	Partial coefficient - control class	1.50
Max. negative pressure in pipe (kPa)	Compression class Normal > 95% SP		
Installation type	Normal trench and normal up to high compaction	Installation factor %	1.0 %
Bedding/bedding layer	Normal levelling layer	Bedding factor %	2.00 %
Traffic load	Heavy traffic load	Max. negative pressure in pipe (kPa)	0.00
Soil cover above pipe top (m) = H	3.20	Distance from ground level to ground-water level (m) = Hw	2.50
Relative density - below ground-water level (kN/m³)	10.00	Relative density - above ground-water level (kN/m³)	20.00
Calculated diameter of pipe (mm)	335.00	Pipe ring stiffness	10.00
Load combination 1.1 Deformation calculation serviceability limit state			
Average stress from traffic load (qtm) kN/m²	17.38	Short-term deformation from variable load (traffic)	0.3 %
Load factor C regarding the stiffness ratio of pipe to backfilling material (applied)	1.00	Short-term deformation from permanent load (soil)	1.3 %
Characteristic traffic load qtk kN/m² (Formula 9)	17.38	Deformation from installation (Table 2.9)	1.0 %
Additional soil cover for determination of	0.87	Average deformation	2.6 %

soil modulus E_{td} when influenced by heavy road traffic load (Table 2.8)

delta H factor dependent on type of road traffic load	1.0	Short-term maximum deformation (Page 42)	4.6 %
Tangent modulus of backfill above ground-water E_{td} (Formula 11) - kN/m ²	5673	Long-term deformation from load (formula 16)	2.4 %
Secant modulus of backfill above ground-water E_{sd} (Formula 12) - kN/m ²	3688	Long-term max. deformation (Formula 15)	6.2 %
Reduction factor for ground-water influence on soil E-moduli (formula 13)	0.91		
Tangent modulus of backfill below ground-water E_{td} (Formula 11 x Formula 13) - kN/m ²	5177		
Secant modulus of backfill below ground-water E_{sd} (Formula 12 x Formula 13) - kN/m ²	3365		

Short-term maximum deformation (Page 42) 4.6 % < 9.0 % (Pipematerial: PP) - OK

Load deformation 2.1 Deformation calculation ultimate limit state			
Calculated ring stiffness (kN/m ²)	5.33	Calculated max. buckling pressure (kN/m ²)	623.66
Calculated tangent modulus (kN/m ²)	2284.58	Design load (kN/m ²)	88.17
Reduction factor beta	0.81	Design buckling pressure (kN/m ²)	506.93

Buckling load combination 2.1 - q_d (Formula 20) kN/m² 88.17 < Buckling load combination 2.1 - $\tilde{B}xq_b$ (Formula 22) 506.93 - OK

Při dodržení zadávacích podmínek potrubí SN 10, DN 300 vyhoví a jeho deformace nepřesáhne hodnotu 4,6 %.

Zadávací podmínky

Použité potrubí: SN 10, DN 300

Krytí nad vrcholem potrubí: 3,6 m

Zatížení provozem: D 400

Hladina spodní vody: 1,6 m pod úrovní terénu

Obsypový materiál: štěrkopísek, lomová drť 0-16

Stupeň zhutnění obsypu: 95 %PS

Result

Calculation OK

Given values			
Pipe type		Pipe dimension (mm)	335
Soil type	Sand		
Safety class	Normal	Control class	Normal
Partial coefficient - safety class	2.27	Partial coefficient - control class	1.50
Max. negative pressure in pipe (kPa)	Compression class Normal > 95% SP		
Installation type	Normal trench and normal up to high compaction	Installation factor %	1.0 %
Bedding/bedding layer	Nominal levelling layer	Bedding factor %	2.00 %
Traffic load	Heavy traffic load	Max. negative pressure in pipe (kPa)	0.00
Soil cover above pipe top (m) = H	3.60	Distance from ground level to ground-water level (m) = Hw	1.60
Relative density - below ground-water level (kN/m³)	10.00	Relative density - above ground-water level (kN/m³)	20.00
Calculated diameter of pipe (mm)	335.00	Pipe ring stiffness	10.00
Load combination 1.1 Deformation calculation serviceability limit state			
Average stress from traffic load (qtm) kN/m²	14.96	Short-term deformation from variable load (traffic)	0.3 %
Load factor C regarding the stiffness ratio of pipe to backfilling material (applied)	1.00	Short-term deformation from permanent load (soil)	1.6 %
Characteristic traffic load qtk kN/m² (Formula 9)	14.96	Deformation from installation (Table 2.9)	1.0 %
Additional soil cover for determination of soil modulus E_{td} when influenced by	0.75	Average deformation	2.9 %

heavy road traffic load (Table 2.8)

delta H factor dependent on type of road traffic load	1.0	Short-term maximum deformation (Page 42)	<u>4.9 %</u>
Tangent modulus of backfill above ground-water E_{td} (Formula 11) - kN/m²	5990	Long-term deformation from load (formula 16)	2.8 %
Secant modulus of backfill above ground-water E_{sd} (Formula 12) - kN/m²	3893	Long-term max. deformation (Formula 15)	6.8 %
Reduction factor for ground-water influence on soil E-moduli (formula 13)	0.78		
Tangent modulus of backfill below ground-water E_{td} (Formula 11 x Formula 13) - kN/m²	4659		
Secant modulus of backfill below ground-water E_{sd} (Formula 12 x Formula 13) - kN/m²	3028		

Short-term maximum deformation (Page 42) 4.9 % < 9,0 % (Pipematerial: PP) - OK

Load deformation 2.1 Deformation calculation ultimate limit state			
Calculated ring stiffness (kN/m²)	5.33	Calculated max. buckling pressure (kN/m²)	591.63
Calculated tangent modulus (kN/m²)	2055.89	Design load (kN/m²)	93.02
Reduction factor beta	0.80	Design buckling pressure (kN/m²)	471.57

Buckling load combination 2.1 - q_a (Formula 20) kN/m² 93.02 < Buckling load combination 2.1 - $\beta \times q_b$ (Formula 22) 471.57 - OK

Print

Při dodržení zadávacích podmínek potrubí SN 10, DN 300 vychoví a jeho deformace nepřesáhne hodnotu 4,9 %.

Zadávací podmínky

Použité potrubí: SN 10, DN 300

Krytí nad vrcholem potrubí: 3,6 m

Zatížení provozem: D 400

Hladina spodní vody: 1,6 m pod úrovní terénu

Obsypový materiál: štěrkopísek, lomová drť 0-16

Stupeň zhutnění obsypu: 90 %PS

Result

Calculation OK

Given values			
Pipe type		Pipe dimension (mm)	335
Soil type	Sand		
Safety class	Normal	Control class	Normal
Partial coefficient - safety class	2.27	Partial coefficient - control class	1.50
Max. negative pressure in pipe (kPa)	Compression class Low > 90% SP		
Installation type	Normal trench and no compaction	Installation factor %	3.0 %
Bedding/bedding layer	Smoothly levelled and surface loosened levelling layer	Bedding factor %	2.00 %
Traffic load	Heavy traffic load	Max. negative pressure in pipe (kPa)	0.00
Soil cover above pipe top (m) = H	3.60	Distance from ground level to ground-water level (m) = Hw	1.60
Relative density - below ground-water level (kN/m³)	10.00	Relative density - above ground-water level (kN/m³)	20.00
Calculated diameter of pipe (mm)	335.00	Pipe ring stiffness	10.00
Load combination 1.1 Deformation calculation serviceability limit state			
Average stress from traffic load (qtm) kN/m²	14.96	Short-term deformation from variable load (traffic)	0.4 %
Load factor C regarding the stiffness ratio of pipe to backfilling material (applied)	1.00	Short-term deformation from permanent load (soil)	2.0 %
Characteristic traffic load qtk kN/m² (Formula 9)	14.96	Deformation from installation (Table 2.9)	3.0 %
Additional soil cover for determination of	0.75	Average deformation	5.4 %

soil modulus E_{ld} when influenced by heavy road traffic load (Table 2.8)

delta H factor dependent on type of road traffic load	1.0	Short-term maximum deformation (Page 42) <u>7.4 %</u>
Tangent modulus of backfill above ground-water E_{ld} (Formula 11) - kN/m ²	4614	Long-term deformation from load (formula 16) 3.6 %
Secant modulus of backfill above ground-water E_{sd} (Formula 12) - kN/m ²	2768	Long-term max. deformation (Formula 15) 9.8 %
Reduction factor for ground-water influence on soil E-moduli (formula 13)	0.78	
Tangent modulus of backfill below ground-water E_{ld} (Formula 11 x Formula 13) - kN/m ²	3589	
Secant modulus of backfill below ground-water E_{sd} (Formula 12 x Formula 13) - kN/m ²	2153	

Short-term maximum deformation (Page 42) 7.4 % < 9.0 % (Pipematerial; PP) - OK

Load deformation 2.1 Deformation calculation ultimate limit state			
Calculated ring stiffness (kN/m ²)	5.33	Calculated max. buckling pressure (kN/m ²)	519.26
Calculated tangent modulus (kN/m ²)	1583.71	Design load (kN/m ²)	93.02
Reduction factor beta	0.71	Design buckling pressure (kN/m ²)	367.12

Buckling load combination 2.1 - q_a (Formula 20) kN/m² 93.02 < Buckling load combination 2.1 - $\beta \times q_b$ (Formula 22) 367.12 - OK

Print

Při dodržení zadávacích podmínek potrubí SN 10, DN 300 vyhoví a jeho deformace nepřesáhne hodnotu 7,4 %.

Zadávací podmínky

Použité potrubí: SN 16, DN 300

Krytí nad vrcholem potrubí: 0,8 m

Zatížení provozem: D 400

Hladina spodní vody: 0,7 m pod úrovní terénu

Obsypový materiál: štěrkopísek, lomová prosíčka 0-8 mm

Stupeň zhutnění obsypy: 95 %PS

Result

Calculation OK

Given values

Pipe type	sewer system	Pipe dimension (mm)	335
Soil type	Sand		
Safety class	Normal	Control class	Normal
Partial coefficient - safety class	2.27	Partial coefficient - control class	1.50
Max. negative pressure in pipe (kPa)	Compression class High > 95% SP		
Installation type	Normal trench and normal up to high compaction	Installation factor %	1.0 %
Bedding/bedding layer	Smoothly levelled and surface loosened levelling layer	Bedding factor %	1.00 %
Traffic load	Heavy traffic load	Max. negative pressure in pipe (kPa)	0.00
Soil cover above pipe top (m) = H	0.80	Distance from ground level to ground-water level (m) = Hw	0.70
Relative density - below ground-water level (kN/m³)	10.00	Relative density - above ground-water level (kN/m³)	20.00
Calculated diameter of pipe (mm)	335.00	Pipe ring stiffness	16.00
Load combination 1.1 Deformation calculation serviceability limit state			
Average stress from traffic load (qtm)	61.93	Short-term deformation	1.4 %

kN/m²		from variable load (traffic)
Load factor C regarding the stiffness ratio of pipe to backfilling material (applied)	1.00	Short-term deformation from permanent load (soil)
Characteristic traffic load qtk kN/m² (Formula 9)	61.93	Deformation from installation (Table 2.9)
Additional soil cover for determination of soil modulus E_{ad} when influenced by heavy road traffic load (Table 2.8)	1.54	Average deformation
delta H factor dependent on type of road traffic load	1.0	Short-term maximum deformation (Page 42)
Tangent modulus of backfill above ground-water E_{ad} (Formula 11) - kN/m²	4446	Long-term deformation from load (formula 16)
Secant modulus of backfill above ground- water E_{ad} (Formula 12) - kN/m²	2890	Long-term max. deformation (Formula 15)
Reduction factor for ground-water influence on soil E-moduli (formula 13)	0.95	
Tangent modulus of backfill below ground-water E_{ad} (Formula 11 x Formula 13) - kN/m²	4223	
Secant modulus of backfill below ground- water E_{ad} (Formula 12 x Formula 13) - kN/m²	2745	

Short-term maximum deformation (Page 42) 3.7 % < 9.0 % (Pipematerial: PP) - OK

Load deformation 2.1 Deformation calculation ultimate limit state			
Calculated ring stiffness (kN/m²)	5.33	Calculated max. buckling pressure (kN/m²)	563.30
Calculated tangent modulus (kN/m²)	1863.74	Design load (kN/m²)	98.09
Reduction factor beta	0.84	Design buckling pressure (kN/m²)	470.66

**Buckling load combination 2.1 - q_d (Formula 20) kN/m² 98.09 < Buckling load combination
2.1 - δ_{buck} (Formula 22) 470.66 - OK**

Při dodržení zadávacích podmínek potrubí SN 16, DN 300 vyhoví a jeho deformace nepřesáhne hodnotu 3,7%.

Zadávací podmínky

Použité potrubí: SN 16, DN 300

Krytí nad vrcholem potrubí: 3,6 m

Zatížení provozem: D 400

Hladina spodní vody: 1,6 m pod úrovní terénu

Obsypový materiál: štěrkopísek, lomová drť 0-16

Stupeň zhutnění obsypu: 90 %PS

Result

Calculation OK

Given values			
Pipe type		Pipe dimension (mm)	335
Soil type	Sand		
Safety class	Normal	Control class	Normal
Partial coefficient - safety class	2.27	Partial coefficient - control class	1.50
Max. negative pressure in pipe (kPa)	Compression class Low > 90% SP		
Installation type	Normal trench and no compaction	Installation factor %	1.0 %
Bedding/bedding layer	Smoothly levelled and surface loosened levelling layer	Bedding factor %	2.00 %
Traffic load	Heavy traffic load	Max. negative pressure in pipe (kPa)	0.00
Soil cover above pipe top (m) = H	3.60	Distance from ground level to ground-water level (m) = Hw	1.60
Relative density - below ground-water level (kN/m³)	10.00	Relative density - above ground-water level (kN/m³)	20.00
Calculated diameter of pipe (mm)	335.00	Pipe ring stiffness	16.00

Load combination 1.1 Deformation calculation serviceability limit state

Average stress from traffic load (qtm) kN/m²	14.96	Short-term deformation from variable load (traffic)	0.4 %
Load factor C regarding the stiffness ratio of pipe to backfilling material (applied)	1.00	Short-term deformation from permanent load (soil)	2.0 %
Characteristic traffic load qtk kN/m² (Formula 9)	14.96	Deformation from installation (Table 2.9)	1.0 %

Additional soil cover for determination of soil modulus E_{td} when influenced by heavy road traffic load (Table 2.8)	0.75	Average deformation	3.4 %
delta H factor dependent on type of road traffic load	1.0	Short-term maximum deformation (Page 42)	<u>5.4 %</u>
Tangent modulus of backfill above ground-water E_{td} (Formula 11) - kN/m²	4614	Long-term deformation from load (formula 16)	3.6 %
Secant modulus of backfill above ground-water E_{sd} (Formula 12) - kN/m²	2768	Long-term max. deformation (Formula 15)	7.8 %
Reduction factor for ground-water influence on soil E-moduli (formula 13)	0.78		
Tangent modulus of backfill below ground-water E_{td} (Formula 11 x Formula 13) - kN/m²	3589		
Secant modulus of backfill below ground-water E_{sd} (Formula 12 x Formula 13) - kN/m²	2153		

Short-term maximum deformation (Page 42) 5.4 % < 9.0 % { Pipematerial: PP1 - OK }

Load deformation 2.1 Deformation calculation ultimate limit state			
Calculated ring stiffness (kN/m²)	5.33	Calculated max. buckling pressure (kN/m²)	519.26
Calculated tangent modulus (kN/m²)	1583.71	Design load (kN/m²)	93.02
Reduction factor beta	0.77	Design buckling pressure (kN/m²)	398.27

Buckling load combination 2.1 - q_x (Formula 20) kN/m² 93.02 < Buckling load combination 2.1 - $\beta \times q_b$ (Formula 22) 398.27 - OK

Při dodržení zadávacích podmínek potrubí SN 16, DN 300 vyhoví a jeho deformace nepřesáhne hodnotu 5,4 %.

LITINOVÉ POTRUBÍ

DN150, DN100

Podklady pro projektanty

Mechanické vlastnosti potrubí

Pevnost v tahu Rm		min. 420 Mpa
Plastická únosnost Rp _{0,2}		min 300 Mpa
Pevnost v tahu za ohybu		min 420 MPa
Vrcholová pevnost v tlaku		min 550 MPa
Modul pružnosti E		170 000 MPa
Možný odklon od podélné osy	DN 100 - 400	6°
	DN 500 - 600	3°
	DN 700	2°

Základní vlastnosti polyuretanove vrstvy

Tloušťka vnitřní vrstvy	DN 80 - 150 DN 200 - 700 DN 100 - 700 DN 100 - 700	1.3 mm 1.3 mm 1.5 mm 1.5 mm
Tloušťka vnější vrstvy		0.9 mm
Teplotní odolnost		90° C dlouhodobě
Rázová odolnost		15 Nm
Pevnost PUR vrstvy v tahu		25 MPa
Povrchová drsnost "K"		0.01 mm
Chemická odolnost	vodní roztok anorganických kyselin a solí	pH 1 - 14
Přilnavost PUR na litinu	pískovaná SA 2 1/2	min. 12 MPa
Dielektrická pevnost PUR		200 - 240 kV/cm
Zkouška ostříkem slanou vodou	po 1000 hod.	bez viditelného poškození
Abrazivní odolnost dle DIN 52108 (ztráta objemu v cm ³ po 16 cyklech)		1,8
Požárně technické vlastnosti	Hořlavost Vývin dýmu	tř. A - nehořlavý dle DIN 4102 st. 3 - slabý vývin dle SIA 183

Maximální průhyb potrubí

Potrubí třídy K9, vzdálenost podpor 6,0 m, zatěžovací síla působí ve středu potrubí.

Jmenovitý průměr	Ohybový moment dle EN 545	Zatížení	Průhyb
DN mm	kNm	kN	d m
80	8	5.33	0.081
100	11.8	7.87	0.067
125	17.9	11.93	0.054
150	25.2	16.8	0.045
200	44.4	29.6	0.034

Povolené tlaky

Tlaky dle normy EN545 2002 pro hrdlové potrubí a tvarovky

DN	Potrubí třídy K9			Potrubí třídy K10		
	PFA	PMA	PEA	PFA	PMA	PEA
40	85	102	107	85	102	107
50	85	102	107	85	102	107
65	85	102	107	85	102	107
80	85	102	107	85	102	107
100	85	102	107	85	102	107
125	85	102	107	85	102	107
150	79	95	100	85	102	107
200	62	74	79	71	85	90
250	54	65	70	61	73	78
300	49	59	64	56	67	72
350	45	54	59	51	61	66
400	42	51	56	48	58	63
500	38	46	51	44	53	58
600	36	43	48	41	49	54
700	34	41	46	38	46	51

PFA:

Povolený provozní tlak.
Nejvyšší hydrostatický tlak, který může potrubí zvládnout v opakových cyklech.

PMA:

Nejvyšší povolený tlak.
Nejvyšší dočasný hydrostatický tlak, zahrnující rázy, který může potrubí zvládnout v opakových cyklech.

PEA:

Testovací tlak.
Nejvyšší hydrostatický tlak, který může nově nainstalované potrubí krátkodobě zvládnout při testech kompletace a těnosti potrubí.

Povolené tlaky pro zámkové spoje

DN	vnitřní zámky		vnější zámkové spoje			zvládnout při testech kompletace a těnosti potrubí.
	Fig. 2807	Fig. 2504-1 (Tyton SIT)	Fig. 2806	Fig. 2805	Fig. 2506	
PFA	PFA	PFA	PFA	PFA	PFA	
80	25	16*	63**			
100	25	16*	63**			
125	25	16*	63**			
150	25	16*	63**			
200	25	16*	63**			
250	16	10	40			
300	16	10	40			
350	16		25			
400	16	10	16	16	16	
500	16		10	16	na poptávku	
600	10		10	16	na poptávku	
700	-		-	16	na poptávku	

* pro potrubí ecopur 10barů

**pro tlaky >40 baru, musí být použito potrubí třídy K10 nebo vyšší